

BUILDING REGULATION COMPLIANCE

Calculation Type: New Build (As Designed)



Property Reference	19037 Plot 054	Issued on Date	21/04/2019
Assessment Reference	54	Prop Type Ref	Epworth
Property	54, The Paddocks, Green Man Road, Navenby, Lincoln, LN5		

SAP Rating	82 B	DER	20.53	TER	20.69
Environmental	86 B	% DER<TER	0.80		
CO ₂ Emissions (t/year)	1.06	DFEE	51.04	TFEE	55.68
General Requirements Compliance	Pass	% DFEE<TFEE	8.33		

Assessor Details	Mr. Robert Atherton, Low Carbon Box Limited, Tel: 07540977134, robert@lowcarbonbox.co.uk	Assessor ID	F291-0001
------------------	--	-------------	-----------

Client	
--------	--

SUMMARY FOR INPUT DATA FOR New Build (As Designed)

Criterion 1 – Achieving the TER and TFEE rate

1a TER and DER

Fuel for main heating	Mains gas		
Fuel factor	1.00 (mains gas)		
Target Carbon Dioxide Emission Rate (TER)	20.69	kgCO ₂ /m ²	
Dwelling Carbon Dioxide Emission Rate (DER)	20.53	kgCO ₂ /m ²	Pass
	-0.16 (-0.8%)	kgCO ₂ /m ²	

1b TFEE and DFEE

Target Fabric Energy Efficiency (TFEE)	55.68	kWh/m ² /yr	
Dwelling Fabric Energy Efficiency (DFEE)	51.04	kWh/m ² /yr	
	-4.7 (-8.4%)	kWh/m ² /yr	Pass

Criterion 2 – Limits on design flexibility

Limiting Fabric Standards

2 Fabric U-values

Element	Average	Highest	
External wall	0.19 (max. 0.30)	0.19 (max. 0.70)	Pass
Party wall	0.00 (max. 0.20)	-	Pass
Floor	0.16 (max. 0.25)	0.16 (max. 0.70)	Pass
Roof	0.11 (max. 0.20)	0.11 (max. 0.35)	Pass
Openings	1.37 (max. 2.00)	1.40 (max. 3.30)	Pass

2a Thermal bridging

Thermal bridging calculated from linear thermal transmittances for each junction

3 Air permeability

Air permeability at 50 pascals	7.00 (design value)	m ³ /(h.m ²) @ 50 Pa	
Maximum	10.0	m ³ /(h.m ²) @ 50 Pa	Pass

Limiting System Efficiencies

4 Heating efficiency

This report has been produced by an accredited Elmhurst member whose work is subject to quality assurance audits. The data used to produce the report has been verified by the Elmhurst members' portal.



BUILDING REGULATION COMPLIANCE

Calculation Type: New Build (As Designed)



Main heating system

Boiler system with radiators or underfloor - Mains gas
Data from database
Vaillant ecoFIT sustain 825 VUW 256/6-3 (H-GB)
Combi boiler
Efficiency: 89.3% SEDBUK2009
Minimum: 88.0%

Pass

Secondary heating system

None

5 Cylinder insulation

Hot water storage

No cylinder

6 Controls

Space heating controls

Programmer, room thermostat and TRVs

Pass

Hot water controls

No cylinder

Boiler interlock

Yes

Pass

7 Low energy lights

Percentage of fixed lights with low-energy fittings

100 %

Minimum

75 %

Pass

8 Mechanical ventilation

Continuous extract system (decentralised)

Specific fan power

0.0900 0.0900 0.1100

Maximum

0.7

Pass

Criterion 3 – Limiting the effects of heat gains in summer

9 Summertime temperature

Overheating risk (East Pennines)

Not significant

Pass

Based on:

Overshading

Average

Windows facing North

5.79 m², No overhang

Windows facing South

3.54 m², No overhang

Windows facing West

1.02 m², No overhang

Air change rate

4.00 ach

Blinds/curtains

None

Criterion 4 – Building performance consistent with DER and DFEE rate

Party Walls

Type

U-value

Filled Cavity with Edge Sealing

0.00

W/m²K

Pass

Air permeability and pressure testing

3 Air permeability

Air permeability at 50 pascals

7.00 (design value)

m³/(h.m²) @ 50 Pa

Maximum

10.0

m³/(h.m²) @ 50 Pa

Pass

10 Key features

Party wall U-value

0.00

W/m²K

Roof U-value

0.11

W/m²K

Door U-value

0.91

W/m²K

This report has been produced by an accredited Elmhurst member whose work is subject to quality assurance audits. The data used to produce the report has been verified by the Elmhurst members' portal.



SUMMARY FOR INPUT DATA

Calculation Type: New Build (As Designed)



Property Reference	19037 Plot 054	Issued on Date	21/04/2019
Assessment Reference	54	Prop Type Ref	Epworth
Property	54, The Paddocks, Green Man Road, Navenby, Lincoln, LN5		

SAP Rating	82 B	DER	20.53	TER	20.69
Environmental	86 B	% DER<TER	0.80		
CO ₂ Emissions (t/year)	1.06	DFEE	51.04	TFEE	55.68
General Requirements Compliance	Pass	% DFEE<TFEE	8.33		

Assessor Details	Mr. Robert Atherton, Low Carbon Box Limited, Tel: 07540977134, robert@lowcarbonbox.co.uk	Assessor ID	F291-0001
------------------	--	-------------	-----------

Client	
--------	--

SUMMARY FOR INPUT DATA FOR: New Build (As Designed)

Orientation	South
Property Tenure	Unknown
Transaction Type	New dwelling
Terrain Type	Suburban
1.0 Property Type	House, Semi-Detached
2.0 Number of Storeys	2
3.0 Date Built	2019
4.0 Sheltered Sides	4
5.0 Sunlight/Shade	Average or unknown

6.0 Measurements

	Heat Loss Perimeter	Internal Floor Area	Average Storey Height
Ground Floor:	15.30 m	28.81 m ²	2.39 m
1st Storey:	15.30 m	28.81 m ²	2.68 m

7.0 Living Area	26.90	m ²
-----------------	-------	----------------

8.0 Thermal Mass Parameter	Precise calculation	
Thermal Mass	222.31	kJ/m ² K

9.0 External Walls

Description	Type	Construction	U-Value (W/m ² K)	Kappa (kJ/m ² K)	Gross Area (m ²)	Nett Area (m ²)
External Wall	Cavity Wall	Other	0.19	72.24	77.57	65.07

9.1 Party Walls

Description	Type	Construction	U-Value (W/m ² K)	Kappa (kJ/m ² K)	Area (m ²)
Party Wall 1	Filled Cavity with Edge Sealing	Single plasterboard on dabs both sides, lightweight aggregate blocks, cavity or cavity fill	0.00	110.00	34.02

9.2 Internal Walls

Description	Construction	Kappa (kJ/m ² K)	Area (m ²)
Internal Partition 2	Plasterboard on timber frame	9.00	62.78
Internal Wall HW	Other	18.44	18.69

10.0 External Roofs

Description	Type	Construction	U-Value (W/m ² K)	Kappa (kJ/m ² K)	Gross Area (m ²)	Nett Area (m ²)
External Roof	External Plane Roof	Plasterboard, insulated at ceiling level	0.11	9.00	28.81	28.81

SUMMARY FOR INPUT DATA

Calculation Type: New Build (As Designed)



10.2 Internal Ceilings

Description	Construction	Kappa (kJ/m ² K)	Area (m ²)
Internal Ceiling 1	Plasterboard ceiling, carpeted chipboard floor	9.00	28.81

11.0 Heat Loss Floors

Description	Type	Construction	U-Value (W/m ² K)	Kappa (kJ/m ² K)	Area (m ²)
Ground Floor	Ground Floor - Solid	Suspended concrete floor, carpeted	0.16	75.00	28.81

11.2 Internal Floors

Description	Construction	Kappa (kJ/m ² K)	Area (m ²)
Internal Floor 1	Plasterboard ceiling, carpeted chipboard floor	18.00	28.81

12.0 Opening Types

Description	Data Source	Type	Glazing	Glazing Gap	Argon Filled	G-value	Frame Type	Frame Factor	U Value (W/m ² K)
Front Door	Manufacture	Solid Door							1.20
Windows	Manufacture	Window	Double Low-E Soft 0.1			0.71		0.70	1.40
HG Door	Manufacture	Half Glazed Door	Double Low-E Soft 0.1			0.71		0.70	1.50
Garage door	Manufacture	Door to Corridor							0.91
Patio Doors	Manufacture	Window	Double Low-E Soft 0.05			0.63		0.70	1.40

13.0 Openings

Name	Opening Type	Location	Orientation	Curtain Type	Overhang Ratio	Wide Overhang	Width (m)	Height (m)	Count	Area (m ²)	Curtain Closed
Front Door	Solid Door	[1] External Wall	South							2.15	
Front Windows	Window	[1] External Wall	South	None	0.00					3.54	
Rear Windows	Window	[1] External Wall	North	None	0.00					5.79	
Side win	Window	[1] External Wall	West	None	0.00					1.02	

14.0 Conservatory

15.0 Draught Proofing

 %

16.0 Draught Lobby

17.0 Thermal Bridging

17.1 List of Bridges

Source Type	Bridge Type	Length	Psi	Imported	Reference:
Independently assessed	E1 Steel lintel with perforated steel base plate	8.86	0.358	No	CBA-312
Independently assessed	E3 Sill	6.47	0.020	No	CBA-314
Independently assessed	E4 Jamb	22.05	0.016	No	CBA-315
Independently assessed	E5 Ground floor (normal)	15.30	0.094	No	CBA-301
Independently assessed	E6 Intermediate floor within a dwelling	15.30	0.000	No	CBA-303
Independently assessed	E10 Eaves (insulation at ceiling level)	8.59	0.036	No	Plasmor
Independently assessed	E12 Gable (insulation at ceiling level)	6.71	0.077	No	CBA-310
Independently assessed	E16 Corner (normal)	10.14	0.051	No	CBA-316
Independently assessed	E18 Party wall between dwellings	10.14	0.018	No	
Table K1 - Default	P1 Party wall - Ground floor	6.71	0.160	No	
Table K1 - Default	P2 Party wall - Intermediate floor within a dwelling	6.71	0.000	No	
Table K1 - Default	P4 Party wall - Roof (insulation at ceiling level)	6.71	0.240	No	

Y-value W/m²K

18.0 Pressure Testing

Designed AP₅₀ m³/(h.m²) @ 50 Pa

SUMMARY FOR INPUT DATA

Calculation Type: New Build (As Designed)



Property Tested ?
 As Built AP₅₀ m³/(h.m²) @ 50 Pa

19.0 Mechanical Ventilation

Summer Overheating

Windows open in hot weather
 Cross ventilation possible
 Night Ventilation
 Air change rate

Mechanical Ventilation

Mechanical Ventilation System Present
 Approved Installation
 Mechanical Ventilation data Type
 Type
 MV Reference Number
 Duct Type

19.1 Mechanical extract ventilation - Decentralised

SFP	Fan/Room Type	Count
0.09	Through Wall Fan Kitchen	1
0.09	Through Wall Fan Other Wet Room	1
0.11	In Room Fan Other Wet Room	1

20.0 Fans, Open Fireplaces, Flues

	MHS	SHS	Other	Total
Number of Chimneys	0		0	0
Number of open flues	0		0	0
Number of intermittent fans				0
Number of passive vents				0
Number of flueless gas fires				0

21.0 Fixed Cooling System

22.0 Lighting

Internal

Total number of light fittings
 Total number of L.E.L. fittings
 Percentage of L.E.L. fittings %

External

External lights fitted
 Light and motion sensor

23.0 Electricity Tariff

24.0 Main Heating 1

Description
 Percentage of Heat %
 Database Ref. No.

SUMMARY FOR INPUT DATA

Calculation Type: New Build (As Designed)



Fuel Type	Mains gas
Main Heating	BGW
SAP Code	104
In Winter	90.2
In Summer	87.3
Controls	CBE Programmer, room thermostat and TRVs
PCDF Controls	0
Delayed Start Stat	No
Sap Code	2106
Flue Type	Balanced
Fan Assisted Flue	Yes
Is MHS Pumped	Pump in heated space
Heat Emitter	Radiators
Flow Temperature	Normal (> 45°C)
Combi boiler type	Standard Combi
Combi keep hot type	None

25.0 Main Heating 2	None
----------------------------	------

Community Heating	None
28.0 Water Heating	HWP From main heating 1
Water Heating	Main Heating 1
Flue Gas Heat Recovery System	No
Waste Water Heat Recovery Instantaneous System 1	No
Waste Water Heat Recovery Instantaneous System 2	No
Waste Water Heat Recovery Storage System	No
Solar Panel	No
Water use <= 125 litres/person/day	Yes
SAP Code	901

29.0 Hot Water Cylinder	None
--------------------------------	------

Recommendations

Lower cost measures

None

Further measures to achieve even higher standards

	Typical Cost	Typical savings per year	Ratings after improvement	
			SAP rating	Environmental Impact
Solar water heating	£4,000 - £6,000	£27	B 84	
	Typical Cost	Typical savings per year	Ratings after improvement	
			SAP rating	Environmental Impact
Solar photovoltaic panels, 2.5 kWp	£5,000 - £8,000	£310	A 97	

ASSESSMENT NOTES

Calculation Type: New Build (As Designed)



Property Reference	19037 Plot 054	Issued on Date	21/04/2019
Assessment Reference	54	Prop Type Ref	Epworth
Property	54, The Paddocks, Green Man Road, Navenby, Lincoln, LN5		

SAP Rating	82 B	DER	20.53	TER	20.69
Environmental	86 B	% DER<TER	0.80		
CO ₂ Emissions (t/year)	1.06	DFEE	51.04	TFEE	55.68
General Requirements Compliance	Pass	% DFEE<TFEE	8.33		

Assessor Details	Mr. Robert Atherton, Low Carbon Box Limited, Tel: 07540977134, robert@lowcarbonbox.co.uk	Assessor ID	F291-0001
------------------	--	-------------	-----------

Client	
--------	--

ASSESSMENT NOTES - Last time updated on: 21.04.2019

U-VALUE CALCULATOR REPORT



Property Reference	19037 Plot 054		Issued on Date	21/04/2019
Assessment Reference	54	Prop Type Ref	Epworth	
Project	54, The Paddocks, Green Man Road, Navenby, Lincoln, LN5			
Calculation Type	New Build (As Designed)			

SAP Rating	82 B	DER	20.53	TER	20.69
Environmental	86 B	% DER<TER	0.80		
CO ₂ Emissions (t/year)	1.06	DFEE	51.04	TFEE	55.68
General Requirements Compliance	Pass	% DFEE<TFEE	8.33		

Assessor Details	Mr. Robert Atherton, Low Carbon Box Limited, Tel: 07540977134, robert@lowcarbonbox.co.uk	Assessor ID	F291-0001
Client			

Building Elements

Floor 000001 - Floor - b&b

Floor Type: Suspended Floor

Area = 28.81 m², Perimeter = 15.30 m, Wall thickness = 300.00 mm, Soil: Clay

Depth of underfloor space below ground: 0.200 m Floor wind shielding: Average (suburban)

Floor height above ground: h = 0.000 m

U-value of walls above ground: U_w = 1.500 m

Ventilation openings per perimeter length: e = 0.0015 %

Mean wind speed: v = 5.000 m/s

Resistance on solum: R_g = 0.000 m²K/W

Layer	Description	Thickness (mm)	Conductivity (W/m ² K)	Resistance (m ² K/W)	Fraction (%)
Ext surface				0.1700	
Layer 1	AAC (600 kg/m³)/ concrete				
	Main construction	100	0.1800	0.5556	86.30
	Main construction	100	1.3500	0.0741	13.70
Layer 2	Jabfloor 100				
	Main construction	150	0.0360	4.1667	100.00
	Corrections - Air Gap: Level 1, Fasteners: None or plastic				
Layer 3	Screed				
	Main construction	75	1.1500	0.0652	100.00
Int surface				0.1700	

Total resistance: Upper limit = 5.056 m² K/W Lower limit = 4.866 m² K/W Average = 4.961 m² K/W

Total correction = 0.0071 m² K/W

U-value (unrounded) = 0.16 W/m² K

Unheated space: None

Total thickness: 325 mm

U-value: 0.16 W/m² K

Kappa: n/a

THERMAL BRIDGING

Calculation Type: New Build (As Designed)



Property Reference	19037 Plot 054	Issued on Date	21/04/2019
Assessment Reference	54	Prop Type Ref	Epworth
Property	54, The Paddocks, Green Man Road, Navenby, Lincoln, LN5		

SAP Rating	82 B	DER	20.53	TER	20.69
Environmental	86 B	% DER<TER	0.80		
CO ₂ Emissions (t/year)	1.06	DFEE	51.04	TFEE	55.68
General Requirements Compliance	Pass	% DFEE<TFEE	8.33		

Assessor Details	Mr. Robert Atherton, Low Carbon Box Limited, Tel: 07540977134, robert@lowcarbonbox.co.uk	Assessor ID	F291-0001
------------------	--	-------------	-----------

Client	
--------	--

	Junction detail	Source Type	Psi (W/mK)	Length (m)	Result	Reference
External wall	E1 Steel lintel with perforated steel base plate	Independently assessed	0.358	8.86	3.17	CBA-312
External wall	E3 Sill	Independently assessed	0.020	6.47	0.13	CBA-314
External wall	E4 Jamb	Independently assessed	0.016	22.05	0.35	CBA-315
External wall	E5 Ground floor (normal)	Independently assessed	0.094	15.30	1.44	CBA-301
External wall	E6 Intermediate floor within a dwelling	Independently assessed	0.000	15.30	0.00	CBA-303
External wall	E10 Eaves (insulation at ceiling level)	Independently assessed	0.036	8.59	0.31	Plasmor
External wall	E12 Gable (insulation at ceiling level)	Independently assessed	0.077	6.71	0.52	CBA-310
External wall	E16 Corner (normal)	Independently assessed	0.051	10.14	0.52	CBA-316
External wall	E18 Party wall between dwellings	Independently assessed	0.018	10.14	0.18	
Party wall	P1 Party wall - Ground floor	Table K1 - Default	0.160	6.71	1.07	
Party wall	P2 Party wall - Intermediate floor within a dwelling	Table K1 - Default	0.000	6.71	0.00	
Party wall	P4 Party wall - Roof (insulation at ceiling level)	Table K1 - Default	0.240	6.71	1.61	

Total: **9.30** W/mK:
 Y-Value: **0.069** W/m²K: