

Energy performance certificate (EPC)

Unit 2D
Alexandria Park
Penner Road
HAVANT
PO9 1QY

Energy rating

C

Valid until: 22 July 2033

Certificate number: 0951-3692-7404-1521-0127

Property type

General Industrial and Special Industrial Groups

Total floor area

452 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's current energy rating is C.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built

19 A

If typical of the existing stock

76 D

Breakdown of this property's energy performance

Main heating fuel

Natural Gas

Building environment

Heating and Natural Ventilation

Assessment level

3

Building emission rate (kgCO₂/m² per year)

11.92

Primary energy use (kWh/m² per year)

94

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/6311-4676-0976-3618-9268\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Jeremy Maltby
Telephone	01962861555
Email	jeremy.maltby@ukesurveys.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/015691
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	UK Energy Surveys
Employer address	The Studio 22 Stanmore Lane Winchester SO22 4AJ
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	18 July 2023
Date of certificate	23 July 2023
