

Energy performance certificate (EPC)

Certificate contents

- Rules on letting this property
- Energy rating and score
- How this property compares to others
- Breakdown of this property's energy performance
- Recommendation report
- Who to contact about this certificate
- Other certificates for this property

Share this certificate

- Email
- Copy link to clipboard
- Print

Unit 01 Trade City Kingsway Luton LU1 1FW		Energy rating <h1>A</h1>
Valid until 30 September 2031	Certificate number 4771-0885-0568-9536-7721	

Property type	B8 Storage or Distribution
Total floor area	349 square metres


Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

You can read [guidance for landlords on the regulations and exemptions](#).

Energy rating and score

This property's energy rating is A.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	30 B
If typical of the existing stock	88 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	4
Building emission rate (kgCO2/m2 per year)	22.36
Primary energy use (kWh/m2 per year)	129

[About primary energy use](#)

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Julian Leese
Telephone	07778 945 446
Email	julian.leese@chb-services.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO000013
Telephone	0330 124 9660
Email	certification@stroma.com

About this assessment

Employer	
Employer address	
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	1 October 2021
Date of certificate	1 October 2021

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

Certificate number	8814-3506-6846-9098-0212
Valid until	5 August 2031

