

Energy performance certificate (EPC)

3, Hackney Road LONDON E2 7NX	Energy rating C	Valid until: 6 August 2029
		Certificate number: 0940-0431-1729-0108-6006


Property type	A1/A2 Retail and Financial/Professional services
Total floor area	70 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	32 B
If typical of the existing stock	93 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	52.64
Primary energy use (kWh/m ² per year)	311

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0080-4976-0421-1910-4000\)](/energy-certificate/0080-4976-0421-1910-4000).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	MOHAMMED SADDIQUE
-----------------	-------------------

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO003628
Telephone	0330 124 9660
Email	certification@stroma.com

About this assessment

Employer	superfastepc@gmail.com 07595959778
Employer address	superfastepc@gmail.com 07595959778
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	1 August 2019
Date of certificate	7 August 2019
