

Energy performance certificate (EPC)

Unit 12 Innovation Business Centre Consul Avenue RAINHAM RM13 8HZ	Energy rating A	Valid until: 6 June 2028
		Certificate number: 0060-1977-0348-3570-6040


Property type	B2 to B7 General Industrial and Special Industrial Groups
Total floor area	54 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is A.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

35 B

If typical of the existing stock

102 E

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	5
Building emission rate (kgCO ₂ /m ² per year)	11.47
Primary energy use (kWh/m ² per year)	93

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/9134-4076-0784-0600-5701\)](https://energy-certificate/9134-4076-0784-0600-5701).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Simon Castledine
Telephone	01522 686964
Email	simon@e-bsolutions.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	CIBSE Certification Limited
Assessor's ID	LCEA031394
Telephone	020 8772 3649
Email	epc@cibsecertification.org

About this assessment

Employer	Simon Castledine
Employer address	Unit B2, The Point Business Park, Weaver Road, Lincoln, LN6 3DH
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	5 June 2018
Date of certificate	7 June 2018