

Energy performance certificate (EPC)

Unit 5 Buntsford Business Centre
Buntsford Drive
Bromsgrove
B60 3FR

Energy rating

C

Valid until: 28 July 2033

Certificate number: 5036-5361-4754-0496-8400

Property type Offices and Workshop Businesses


Total floor area 204 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

10 A

If typical of the existing stock

39 B

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	4
Building emission rate (kgCO ₂ /m ² per year)	8.18
Primary energy use (kWh/m ² per year)	88

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0435-5996-8556-0286-5432\)](/energy-certificate/0435-5996-8556-0286-5432).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Anosike Anthony
Telephone	07886 277818
Email	tony@energaia.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/027430
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Energaia
Employer address	11 Caithness Crescent, Manor Kingsway, Derby, Derbyshire, DE22 3XS
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	7 July 2023
Date of certificate	29 July 2023