

Energy performance certificate (EPC)

GM Group Holdings
GM House
Wilkinson Way
BLACKBURN
BB1 2EH

Energy rating

C

Valid until: 8 May 2029

Certificate number: 9481-3015-0813-0800-1905


Property type	B1 Offices and Workshop businesses
Total floor area	2,889 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

34 B

If typical of the existing stock

101 E

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	62.67
Primary energy use (kWh/m ² per year)	370

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0140-0841-8839-1105-9006\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Neil Austin - 01253 486 919
Telephone	01253486919
Email	neil.austin@ener-services.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/017379
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Ener Services & Surveys Ltd
Employer address	Airey House Shepherd Road Lytham St Annes
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	9 May 2019
Date of certificate	9 May 2019
