

Energy performance certificate (EPC)

FIRST FLOOR OFFICE
23 Charlotte Road
LONDON
EC2A 3PB

Energy rating

C

Valid until: **22 September 2029**

Certificate number: **0696-9111-2130-1900-7123**

Property type B1 Offices and Workshop businesses

Total floor area 101 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built	26 B
If typical of the existing stock	77 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	45.04
Primary energy use (kWh/m2 per year)	266

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0910-7996-0421-1112-1064\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Name
Telephone	01892 300 450
Email	enquiries@jcmlconsultancy.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID300156
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Employer	Greenfish (JCML)
Employer address	177 Silverdale Rd, Tunbridge Wells TN4 9HT
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	19 September 2019
Date of certificate	23 September 2019