

Energy performance certificate (EPC)

Unit 8 Langley Park
Waterside Drive
Langley
SLOUGH
SL3 6AD

Energy rating

B

Valid until:

18 November 2035

Certificate number:

9572-0340-5122-7564-5156

Property type

Storage or Distribution

Total floor area


521 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

13 A

If typical of the existing stock

53 C

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	5
Building emission rate (kgCO ₂ /m ² per year)	5.83
Primary energy use (kWh/m ² per year)	62

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/4634-6687-4151-0585-5520\)](/energy-certificate/4634-6687-4151-0585-5520).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Mark Walton
Telephone	07515 329 786
Email	mark.walton@meessolutions.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	CIBSE Certification Limited
Assessor's ID	LCEA181643
Telephone	020 8772 3649
Email	epc@cibsecertification.org

About this assessment

Employer	MEES Solutions Ltd
Employer address	Unit 5 Ram Court Wicklesham Farm Faringdon SN7 7PN
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	19 November 2025
Date of certificate	19 November 2025
