

Energy performance certificate (EPC)

Unit 9F Farnham Trading Estate Farnham GU9 9NN	Energy rating C	Valid until: 27 January 2032
		Certificate number: 5092-5398-3335-3727-0159

Property type B1 Offices and Workshop businesses

Total floor area 409 square metres


Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/government/publications/non-domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/government/publications/non-domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property’s carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

31 B

If typical of the existing stock

91 D

Breakdown of this property’s energy performance

Main heating fuel

Natural Gas

Building environment

Heating and Natural Ventilation

Assessment level	3
Building emission rate (kgCO₂/m² per year)	39.74
Primary energy use (kWh/m² per year)	247

► [About primary energy use](#)

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/5140-2174-7556-9498-3877\)](/energy-certificate/5140-2174-7556-9498-3877).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Michael Leckie
------------------------	----------------

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO035355
Telephone	0330 124 9660
Email	certification@stroma.com

About this assessment

Employer	Leckie Assessing
-----------------	------------------

Employer address	10 Silisrtira Close, Knaphill, Woking, Surrey, GU212TL
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	27 January 2022
Date of certificate	28 January 2022

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.



[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/KX25htGMX5\)](https://forms.office.com/e/KX25htGMX5)

[Service performance \(/service-performance\)](#)

OGI

All content is available under the [Open Government Licence v3.0 \(https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/\)](#), except where otherwise stated



© Crown copyright (<https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-copyright/>)