

Energy performance certificate (EPC)

Unit G10, Silverbox Magnet Road East Lane WEMBLEY HA9 7RG	Energy rating <h1 style="font-size: 2em; margin: 0;">D</h1>	Valid until: 17 June 2029 <hr/> Certificate number: 0940-2930-0391-0610-8010
---	--	---

Property type B1 Offices and Workshop businesses

Total floor area 186 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

If a property has an energy rating of F or G, the landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.

Energy efficiency rating for this property

This property's current energy rating is D.



Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built 67 | C

If typical of the existing stock 197 | G

Properties are given a rating from A+ (most efficient) to G (least efficient).

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	4
Building emission rate (kgCO ₂ /m ² per year)	19.69
Primary energy use (kWh/m ² per year)	113

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/9201-4014-0319-0800-6091\)](#).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	laiq shaikh
Telephone	07960300832
Email	zeehips@gmail.com

Accreditation scheme contact details

Accreditation scheme	Stroma Certification Ltd
Assessor ID	STRO002700
Telephone	0330 124 9660
Email	certification@stroma.com

Assessment details

Employer	Zeehips limited. Email zeehips@gmail.com
Employer address	408 ,legacy centre hanworth trading estate ,feltham ,tw13 6dh Mobile07960300832
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	16 April 2019
Date of certificate	18 June 2019
