Energy performance certificate (EPC) recommendation report

Featherstone 253 Lavender Hill LONDON SW11 1JW Report number **0910-9953-0421-5690-1034**

Valid until **26 September 2029**

Energy rating and EPC

This property's energy rating is D.

For more information on the property's energy performance, see the EPC for this property.

Recommendations

Recommendation

Changes that may pay for themselves within 3 years

Recommendation	Potential impact on carbon emissions
Replace tungsten GLS lamps with CFLs: Payback period dependent on hours of use.	Low
Consider replacing T8 lamps with retrofit T5 conversion kit.	Medium
In some spaces, the solar gain limit defined in the NCM is exceeded, which might cause overheating. Consider solar control measures such as the application of reflective coating or shading devices to windows.	Medium

Changes that may pay for themselves within 3 to 7 years

Recommendation	Potential impact on carbon emissions
Add time control to heating system.	Low

Changes that may pay for themselves in over 7 years

	emissions
Install more efficient water heater.	Low
Add optimum start/stop to the heating system.	Medium
The default chiller efficiency is chosen. It is recommended that the chiller system be investigated to gain an understanding of its efficiency and possible improvements.	Low
The default heat generator efficiency is chosen. It is recommended that the heat generator system be investigated to gain an understanding of its efficiency and possible improvements.	Low
Some walls have uninsulated cavities - introduce cavity wall insulation.	Medium

Property and report details

27 September 2019
80 square metres
Air Conditioning
CLG, iSBEM, v5.6.a, SBEM, v5.6.a.0

Potential impact on carbon

Assessor's details

Jeff Spencer
07498 200 387
jspencer@londonion.co.uk
londonion
londonion
STRO033883
The assessor is not related to the owner of the property.
Stroma Certification Ltd