Energy performance certificate (EPC)

1-3 Robertson Street HASTINGS TN34 1HN Energy rating

Valid until:	8 October 2027
Certificate number:	0210-6939-0383-8680-7014


Property type	A1/A2 Retail and Financial/Professional services
Total floor area	8,080 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	32 B
If typical of the existing stock	95 D

Breakdown of this property's energy performance

Main heating fuel	Oil
Building environment	Air Conditioning
Assessment level	4
Building emission rate (kgCO2/m2 per year)	95.63
Primary energy use (kWh/m2 per year)	529

Recommendation report

Guidance on improving the energy performance of this property can be found in the recommendation report (/energy-certificate/9681-4081-0338-0700-6925).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	George Lamont
Telephone	01225 753 755
Email	george@greenrockenergy.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited	
Assessor's ID	QUID205721	
Telephone	01225 667 570	
Email	info@quidos.co.uk	
About this assessment		

Employer	GreenRock Energy
Employer address	11 Dunkirk Business Park Southwick
	Trowbridge Wilts BA14 9NL
Assessor's declaration	The assessor is not related to the owner of the
	property.
Date of assessment	26 September 2017
Date of certificate	9 October 2017