# **Energy performance certificate (EPC)**

29 Trafalgar Street BRIGHTON BN1 4ED Energy rating

Valid until: 29 April 2029

Certificate number:

9962-3004-0614-0900-0471

Property type

A1/A2 Retail and Financial/Professional services

Total floor area


71 square metres

# Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

# **Energy rating and score**

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

# How this property compares to others

Properties similar to this one could have ratings:

If newly built

22 A

If typical of the existing stock

63 C

## Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	66.68
Primary energy use (kWh/m2 per year)	394

# **Recommendation report**

Guidance on improving the energy performance of this property can be found in the  $\underline{\text{recommendation report}}$  ( $\underline{\text{recommendation report}}$ ).

# Who to contact about this certificate

### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Stuart Foster
Telephone	01273 458484
Email	info@skyline-epc.com

#### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/007985
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

### **About this assessment**

6 Skyline View, Peacehaven, BN10 8EL
5 5.ty5 115.ty, 1 5455.ta15.ty, 21115 522
The assessor is not related to the owner of the property.
30 April 2019
30 April 2019
_