

Energy performance certificate (EPC)

City House
126-130 Hills Road
CAMBRIDGE
CB2 1RE

Energy rating

C

Valid until: 31 May 2033

Certificate number: 0852-1972-1554-2732-9999

Property type Offices and Workshop Businesses


Total floor area 10,669 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

18 A

If typical of the existing stock

73 C

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Air Conditioning
Assessment level	4
Building emission rate (kgCO ₂ /m ² per year)	23.4
Primary energy use (kWh/m ² per year)	184

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/1788-3102-8292-5108-8980\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Richard Phillips
Telephone	07740286213
Email	richard@waverleyenergyassessments.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/010555
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Waverley Surveys Ltd
Employer address	Flat, Post Office Abbots Ann SP11 7AZ
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	3 May 2023
Date of certificate	1 June 2023
