Ground floor

FIRE SAFETY LEGEND

30minute Fire Resistant Door Fitted With Self Closer & Intumescent Smoke Seals Or Designated 'Keep Locked /Shut' and Duly Signed In Accord With Approved Document B. All Final Exit Doors To Be Provided With Ironmongery In Accordance With BS EN : 1125 : 1997

S 13 — Fire Door keep shut

S 14 — Fire Door keep locked

S 20 — Fire Escape Keep Clear.

S 22 — Fire Exit, Or Emergency Exit Notice, Or Equivalent Graphic Symbol

S 23 — Slide to open (with arrow indicating direction)

BS 5499: Part 4 : 2000

WATER FIRE EXTINQUISHER

CARBON DIOXIDE FIRE EXTINQUISHER

FOAM FIRE EXTINQUISHER

FIRE BLANKET IN CONTAINER

HD — HEAT DETECTOR

SD — SMOKE DETECTOR

SD — SMOKE DETECTOR WITH SOUNDER

B — BEACON

All In Accord With BS 5839 Pt 1 2002

MANUAL BREAK GLASS UNIT/ CALL POINT

MANUAL BREAK GLASS UNIT/ CALL POINT WITH SECONDARY COVER
Fire Alarm Call Point With Fire Action Sign Adjacent, The Contents Of Which Are Based On The Fire Safety And Evacuation Plan For The Premises. Type L1 System Linking Into System Of Main Building.

E — Area Covered With System Of Escape Lighting Which Will Illuminate The Area Upon Failure Of The Normal Lighting Power Supply, To A Sufficient Standard To Enable Persons To Leave The Area Safely.

E_F -- STORM ELD-1/110/WH/NM-3W LED- Front of house

E_B -- STORM ELD-4/OP-1X3W LED- Back of house

EXIT SIGNAGE(In accordance with BS 5266 Part 1: 1999 and Approved Document B. Also BS 5499 Pt 4 2000 Respectively.

M -- Maintained (Continuous Electricity Supply)
NM -- Non Maintained
SM -- Surface Mounted
R -- Recessed Light
B -- Bulkhead Light with Running Man Logo
GBC -- STORM glass blade recessed in ceiling with running man logo. (SLS-671915.004+ 981883.004/WH-1X2.2W)

ARROW INDICATES DIRECTION TO EXIT

REPEATER PANEL

FIRE ALARM PANEL

ANSUL — "ANSUL" FIRE SUPPRESSION SYSTEM

AAS — "ANSUL" ACTIVATION SWITCH

SF — Doors To Have A Simple Fastening Which Is Easily & Immediately Openable By A Person On His Way Out Without Use Of A Key.Eg Barrel Bolts, Night Latch,Lever Handle Etc

PB — (Doors Which Are To Be Provided With A Panic-Bolt There Must Be A Notice Adjacent To The Fastening Indicating The Method Of Opening (Min 5mm Lettering)

VP — Vision Panel Port Holes

SCA — Self-Closing Door Incorporating An Automatic Release eg. Electro Magnetic Door Holder

FFF — Doors free from fastenings (other than a ball or roller fastening or lever handled latch). This is to ensure the door is always available for escape from either side

Fire escape from the building

DIMISE LINE

Fire Detection Will Be Installed To All Void Areas Exceeding 900mm.
The Fire Alarm To Be Installed Is To Be L1

Scale 0 1 2 3 4 5m

General Notes

All Dimemsions To Be Checked And Verified On Site.

Please Report Omissions And Any Discrepancies To The Designers Immediately.

All Works To Comply With Current Building Regulations

If Printed From A PDF This Drawing Is Not To Scale And Is Therefore For Reference Only

Rev.	Date	Revised By	Comments

Client **McQueen**

Project McQueen 55-61 Tabernacle St, Old Street, London EC2A 4AA	Designed: ...	Project No:
	Drawn: RA	Scale: 1:50 @ A1 1:100 @ A3
Drawing Title Ground floor - licensing layout as proposed.	Checked:	Drawing No: 501
	Date: Aug 2020	Revision:
	Issued For:	

Cotton Thompson Cole Ltd.
Design + Construction Consultants

Cotton Thompson Cole
4 St Marks Place,
Wimbledon,
London,
SW19 7ND

Telephone 020-8971-7600

www.cottonthompsoncole.co.uk