

Energy performance certificate (EPC)

The Hub
Fowler Avenue
FARNBOROUGH
GU14 7JP

Energy rating

D

Valid until: **9 June 2029**

Certificate number: **9494-3077-0517-0800-3921**

Property type **B1 Offices and Workshop businesses**


Total floor area **5,438 square metres**

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

32 B

If typical of the existing stock

93 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Air Conditioning
Assessment level	4
Building emission rate (kgCO ₂ /m ² per year)	62.93
Primary energy use (kWh/m ² per year)	371

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0340-0841-9579-4727-9002\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Jonathan Parkes
Telephone	01922 898171
Email	jonathan@midlandassessenergy.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/005659
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Midland Assess Energy
Employer address	c/o LBParkes, Town Wharf Business Park, 16-18 Station Street, Walsall, WS2 9JZ
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	27 March 2019
Date of certificate	10 June 2019
