DRG. No.

FIRE LEGEND.

- (EL) EMERGENCY LIGHTING
- (SD) SMOKE DETECTOR
- (HD)(FT) HEAT DETECTOR FIXED TEMP.
- AUDIBLE WARNING DEVICE (BELL)
- CALL POINT.
- (1SES) ILLUMINATED EMERGENCY EXIT SIGN.
- (RMES) ILLUMINATED EMERGENCY EXIT SIGN. RUNNING MAN.
- (W) WATER EXTINGUISHER
- (DP) DRY POWDER EXTINGUISHER.
- EMERGENCY LIGHTING (EXTERNAL)

EMERGENCY SIGNAGE TO BE FIXED AT ALL EMERGENCY EXITS AND ESCAPE ROUTES TO BS 5499

INSURERS CERTIFICATE REQUIRED FOR EMERGENCY LIGHTING AND FIRE ALARM SYSTEM.

NOTE.
ALL INTERNAL AND EXTERNAL DOORS TO HAVE MIN CLEAR OPENING WIDTH OF 800mm.

First Floor

fire escape (STEEL)
1850 (NOT TO SCALE)
down
EMERGENCY EXIT PANIC BAR OPENING.
canteen
SMP ENCASED AND TO TERMINATE MIN 600mm ABOVE ROOFLINE WITH BALLOON GRATING.
ENCASE STEELWORK
passage 'c'
150mm LIGHTWEIGHT CONCRETE BLOCKWORK
area 9
office area 12
passage 'b'
gents
ladies
3/4 HEIGHT PANEL PARTITIONS.
STUB STACK WITH AUTOMATIC AIR VALVE
office area 8
board room
meeting room
landing
office area 10
office area 11
office area 13
DEMOUNTABLE PARTITIONING.
SLIDING FOLDING PARTITION.
ENCASE STEELWORK W/BLOCKWORK AS BELOW.
1200 x 1200 LANDING.
DEMOUNTABLE PARTITIONS TO BE KNEE GLAZED TO ALLOW VISIBILITY TO ESCAPE ROUTE.
PARTITION WALL DIRECTLY OVER RECEPTION DESK. SPAN OF 2x140 WALL NOT CENTRE AS SHOWN.
WIDTH OF OPENING TO BE DECIDED.
BALUSTRADE AS FLOORING TO STAIRWELL.
150mm VERTICAL DPC'S TO ALL NEW OPENINGS
down
up
ramp (max 1 in 12 fall)
emergency exit
PANIC BAR OPENING.
225 x 225 2½ BRICKS FIXED AT FFL + 300mm AND FFL + 2000 max.
1800 x 2025
1800 x 1200
1800 x 600
1800 x 1800
1800 x 1200 DP
1800 x 600 DP
1800 x 2025 DP
1800 x 2025
1800 x 1200 DP
1800 x 1200
1800 x 1200 DP
1800 x 1200 DP
1800 x 1200 DP