

Energy performance certificate (EPC)

Rear Of
113 Broadway
LEIGH-ON-SEA
SS9 1PG

Energy rating

D

Valid until: **10 April 2032**

Certificate number: **1328-2690-6564-5627-9198**

Property type **B1 Offices and Workshop businesses**

Total floor area **24 square metres**

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built

38 B

If typical of the existing stock

110 E

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	67.47
Primary energy use (kWh/m ² per year)	399

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0747-9674-0868-7394-0681\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Mark Surry
Telephone	01375850520
Email	marksurry@futureenergyconsulting.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/019415
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Future Energy Consulting
Employer address	7 Alexandra Way East Tilbury Essex RM18 8NT
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	11 April 2022
Date of certificate	11 April 2022
