

Energy performance certificate (EPC)

129a Weedington Road LONDON NW5 4NX	Energy rating 	Valid until: 10 September 2029
		Certificate number: 9614-3048-0419-0100-2725


Property type	B1 Offices and Workshop businesses
Total floor area	169 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

36 B

If typical of the existing stock

106 E

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity	
Building environment	Heating and Natural Ventilation	
Assessment level	3	
Building emission rate (kgCO2/m2 per year)	23.46	
Primary energy use (kWh/m2 per year)	139	

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0260-0141-1499-4428-7006\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	M M Rauf
Telephone	07878 466 055
Email	muj_is@hotmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO001523
Telephone	0330 124 9660
Email	certification@stroma.com

About this assessment

Employer	Commercial EPC Ltd
Employer address	www.lepcco.co.uk
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	22 August 2019
Date of certificate	11 September 2019