



24 Northcote Avenue, Sunderland, SR1 2RP

Three-bed Mid-Terrace House

- No Chain Attached
- 3-Bed Mid-Terrace House
- Private Rear Yard
- Original Victorian Features
- Refurbishment Opportunity
- Vacant Possession
- Close to Sunderland City Centre

Summary

Available Size	110 sq m
Price	£75,000
Business Rates	Upon Enquiry
Car Parking	Permit parking
VAT	Not applicable
Legal Fees	Each party to bear their own costs
EPC Rating	C

Description

24 Northcote Avenue is a three-bedroom mid-terrace property for sale with vacant possession. The property comprises of an entrance hallway, lounge, dining room, kitchen and bathroom across the ground floor. The upper floor level offers three spacious rooms including two double and one single bedrooms with high ceilings throughout. Externally, the property features on-street parking permits to the front and a rear garden. Restrictive Covenant has been issued to the property, which does not allow for HMO uses and subject to private treaty purchasers only.

Location

Northcote Avenue is a well-situated location in Sunderland, offering convenient access to local amenities and transport links. The area benefits from nearby shops, schools, and leisure facilities, all within easy reach. Excellent public transport connections provide quick access to Sunderland city centre and surrounding areas, making Northcote Avenue an ideal location for both families and commuters.

Accommodation

The accommodation comprises the following areas:

Name	sq ft	sq m	Availability
Building	1,184.03	110	Available
Total	1,184.03	110	

Money Laundering Regulations


Please note that any offers will require you to be financially verified, meaning you'll need to provide us sight of a mortgage in principle, proof of deposit funds, and proof of cash. You'll also need to provide us with full chain details including agents and solicitors down the chain. To comply with Money Laundering Regulations all buyers will be required to provide us with proof of identification before we can issue acceptance letters and solicitors are instructed.

Material Information

The information provided about this property does not constitute or form part of an offer or contract, nor may it be regarded as representations. All interested parties must verify accuracy and your solicitor must verify tenure and lease information, fixtures and fittings and, where the property has been recently constructed, extended or converted, that planning/building regulation consents are in place. All dimensions are approximate and quoted for guidance only, as are floor plans which are not to scale and their accuracy cannot be confirmed. Reference to appliances and/or services does not imply that they are necessarily in working order or fit for purpose.

Council Tax

The GOV.UK website states the property is Council Tax Band: A



Viewing & Further Information




Amber Crampton
01609 797 330

amber.crampton@alignpropertypartners.co.uk



Kelsey Collins
01609 797 330 | 07498758137
kelsey.collins@alignsurveyors.co.uk

View Properties Here
www.alignsurveyors.co.uk



Energy performance certificate (EPC)

24, Northcote Avenue
SUNDERLAND
SR1 2RP

Energy rating

C

Valid until:

18 November 2026

Certificate number:

9118-4907-7259-4976-7980

Property type

Mid-terrace house

Total floor area

68 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's energy rating is C. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60

Score	Energy rating	Current	Potential
92+	A		
81-91	B		83 B
69-80	C	69 C	
55-68	D		
39-54	E		
21-38	F		
1-20	G		

Breakdown of property’s energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property’s age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, filled cavity	Good
Roof	Pitched, 200 mm loft insulation	Good
Window	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in 67% of fixed outlets	Good
Floor	Suspended, no insulation (assumed)	N/A
Secondary heating	Room heaters, mains gas	N/A

Primary energy use

The primary energy use for this property per year is 233 kilowatt hours per square metre (kWh/m2).

How this affects your energy bills

An average household would need to spend **£674 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £49 per year** if you complete the suggested steps for improving this property’s energy rating.

This is **based on average costs in 2016** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 7,385 kWh per year for heating
 - 1,976 kWh per year for hot water
-

Impact on the environment

This property's environmental impact rating is D. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year.

Carbon emissions

An average household produces 6 tonnes of CO₂

This property produces 2.8 tonnes of CO₂

This property's potential production 1.6 tonnes of CO₂

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

Step	Typical installation cost	Typical yearly saving
1. Low energy lighting	£20	£13
2. Solar water heating	£4,000 - £6,000	£36
3. Solar photovoltaic panels	£5,000 - £8,000	£273

Advice on making energy saving improvements

[Get detailed recommendations and cost estimates \(www.gov.uk/improve-energy-efficiency\)](http://www.gov.uk/improve-energy-efficiency)

Help paying for energy saving improvements

You may be eligible for help with the cost of improvements:

- Heat pumps and biomass boilers: [Boiler Upgrade Scheme \(www.gov.uk/apply-boiler-upgrade-scheme\)](http://www.gov.uk/apply-boiler-upgrade-scheme)

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Gary Morgan
Telephone	0207 409 8737
Email	dea3@savills.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	NHER
Assessor's ID	NHER009693
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	19 November 2016
Date of certificate	19 November 2016
Type of assessment	RdSAP
