

Certificate of Product Approval

Certificate Number: 1000j

Issue: 01

Burton Safes Limited

Units 20 – 28
Brockholes Business Park
Rock Mill Road
Brockholes
Holmfirth
HD9 7BN

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product

Keyguard Digital XL
key safe

Standard

LPS 1175: Issue 8
Requirements and testing procedures for the LPCB approval and listing of intruder resistant building components, strongpoints, security enclosures and free-standing barriers

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Paul Dillon
Verifier

5 April 2019
Date of Issue

5 April 2019
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1000j Burton Safes Limited

Issue: 01

Key Safe

Product Name	Type	Security Rating	LPCB Ref. No.
Keyguard Digital XL	Wall mounted key safe with twelve button combination	A3	1000j/01

Installation Instructions and Substrates

Product	Installation Instructions	Substrate ¹	
		Brickwork, Concrete, Stone or Steelwork	Rendered Brickwork, Concrete, Stone or Steelwork ²
Keyguard Digital XL	Anchor Fixing Bolts - V5 (25/02/19)	✓	-
	50 mm Concrete Screw - V1 (26/03/19)	✓	-
	75 mm Render Fixing Bolts - V1 (25/02/19)	-	✓
	100 mm Render Fixing Bolts - V1 (25/02/19)	-	✓
	Standard Fixing Bolts – V5 (25/02/19)	✓	✓

Notes:

1. The approval does not cover the key safes when mounted to alternative substrates.
2. The approval covers renders up to 20 mm thick.
3. The key safe is approved when secured using a code at least 3-digits long.

This certificate and appendix is maintained and held in force through regular surveillance activities

P. Dillon

Signed for BRE Global Ltd.

Paul Dillon
Verifier

5 April 2019
Date of Issue

5 April 2019
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre