

Declaration of Performance
**CONSTRUCTION PRODUCTS REGULATION 2011
DECLARATION OF PERFORMANCE**
No. AL-0000402076

1. Unique identification code of the product-type:

Briton 389.N, 389M.N and 389OEM.N

Accessories: - 379MDS, Briton 1413/LE & 1413/KE

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

Briton 389.N, 389M.N and 389OEM.N

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

**For use on fire and smoke compartmentation doors
Or
Escape route doors**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

**Allegion
Bescot Crescent
Walsall
WS1 4DL**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

EN 179: 2008

Notified testing laboratory No.1121 performed the type testing and issued test reports.

8. European Technical Assessment:

N/A

9. **Declared performance**

Essential characteristics	Performance	Harmonised technical specification
Clause 4.2.1 Ability to release (for doors on escape routes)		
Release function Release operation Lever handle Push pad Double doorset Exposed edges and corners Push pad installation Lever handle installation Operating element projection Operating element face (Lever handle)	< 1 sec Pass N/A Pass Pass > 0,5 mm Z < 250 mm N/A W< 100mm or 150mm N/A	EN 179:2008

<p>Operating element face (Push pad) Lever handle operating gap Push pad operating gap Test rod Push pad release operation Accessible gap Door free movement Top vertical bolt Keepers Keepers dimensions Door mass and dimensions</p> <p>Outside access device Release forces</p> <p>Security requirement</p>	<p>≥1400mm² N/A Pass Pass Pass Pass Pass N/A Pass Pass <i>Door mass ≤ 200 Kg, door height ≤ 2520 mm, door width ≤ 1320 mm</i></p> <p>Pass Type B < 150 N</p> <p>Grade 2, 3, 4 or 5</p>	
<p>Clause 4.2.1 Durability of ability to release against aging and degradation (for doors on escape routes)</p>		
<p>Corrosion resistance Temperature range</p> <p>Covers for vertical rods Lubrication Re-engagement force Durability Abuse resistance – Operating element Abuse resistance – Vertical rod Final examination</p>	<p>Grade 3: 96 h Operating forces at -10 C° and + 60 C° < 50% in excess of the operating forces at +20 C° N/A Lubrication every 20 000 cycles < 50 N Grade 7: 200 000 cycles 500 N & 1000N N/A Type B < 150 N</p>	
<p>Clause 4.2.1 Self closing ability C (for fire/smoke doors on escape routes) Re-engagement force</p>	<p>< 50 N</p>	
<p>Clause 4.2.1 Durability of self closing ability C against aging and degradation (for fire/smoke doors on escape routes) Durability Re-engagement force</p>	<p>Grade 7: 200 000 cycles < 50 N</p>	
<p>Clause 4.2.1 Resistance to fire E (integrity) and I (insulation) (for fire doors on escape routes) Suitability of panic exit devices for use on fire resisting doorsets assemblies –</p> <p>Additional requirements</p>	<p>Grade B: Suitable for use on fire/smoke door assemblies. A single leaf steel door assembly fitted with this device passed a fire test against EN 1634-1 Pass</p>	
<p>Clause 4.1.25 Control of Dangerous substances</p>	<p>If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the hinge do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)</p>	

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.
Signed for and on behalf of the manufacturer by:

Chris Crampton
Controller - Unitary EMEA, Finance and Accounting

A handwritten signature in black ink, appearing to read 'C Crampton', with a long horizontal flourish extending to the right.

Allegion,
Bescot Crescent,
Walsall,
WS1 4DL

20th April 2015