

Precautions

Installation Notes

- ▶ Install in accordance with the IEE wiring regulations and building regulations.
- ▶ This product must be installed by a suitably competent person.

Electrical

- ▶ Switch the power off at the mains supply before installing or maintaining the unit.
- ▶ Ensure others cannot restore the electrical power supply without your knowledge.
- ▶ Only install compatible constant voltage LED fixtures and controls. 12V products should be used with a 12V driver and 24V products should be used with a 24V driver. Contact technical support or visit the product page for compatible products.
- ▶ Connect products with correct polarity. The positive cable (+) should be connected to the positive terminal on the driver. The negative cable (-) should be connected to the negative terminal on the driver.
- ▶ Ensure that the power capacity of the LED driver is greater than the total load of all the connected products.
- ▶ Ensure appropriate cables are installed between driver, fixtures, and any controllers. When choosing cable, factor in voltage drop, current rating and type. Inadequate cables could overheat and cause a fire.
- ▶ The maximum length of output cable to the light source should not exceed 2 metres to meet EMC standard.
- ▶ Do not install if the product has visible damage.
- ▶ Do not open, modify, or repair the unit. No user-serviceable parts inside.
- ▶ This is a Class II product: no earth connection is required.
- ▶ Ensure input voltage matches rating on device label.
- ▶ Maintain a clearance of 50mm around the unit.
- ▶ Connect AC mains to input terminals (L/N). No earth is required.
- ▶ Do not short-circuit the output.

Mechanical

- ▶ The unit will generate heat during use. Do not cover with insulation or place near flammable materials.
- ▶ Secure unit to a solid surface using fixing points with adequate ventilation.
- ▶ Protect the driver from mechanical damage. Take care not to dislodge any components during installation. Ensure that cables connected to the driver cannot be pulled and are secured to provide strain relief.

Environmental

- ▶ IP20 drivers are not waterproof and can only be installed indoors.
- ▶ IP66 and IP67 drivers are suitable for indoor and outdoor installation.
- ▶ Install in a location without chemicals like sulphur, acid and halogen present.
- ▶ Avoid direct exposure to sunlight and protect cables from UV rays with suitable silicone sheath.

Product Warranty

1. A warranty period is provided for products in normal use. For any faults arising during the period that are confirmed to be quality related by inspection by the company, a product of the same specification will be replaced for free.
2. The warranty does not cover any of the following:
 - (1) Any product damage due to usage not allowed in the instructions.
 - (2) Any product damage due to disassembling or wrong operation by the user.
 - (3) Severe appearance damage or deformation of the product.

IMPORTANT

- ▶ Please read these instructions carefully before commencing any work.
- ▶ Please retain these instructions for future reference.
- ▶ Please refer to product listing for detailed information.

CLASS II

Non-Dimmable LED Drivers

▶ 12V Constant Voltage



User Manual



WARNING
Shock hazard. May result in serious injury or death. Isolate supply before installation. Complete electrical safety checks before commissioning. Inspect regularly in accordance with local regulations




WARNING
Risk of fire. Ensure correct cable sizing, over-current protection, ventilation and keep away from combustible materials.

SKU	INPUT		OUTPUT			PF	Eff.	Ta (Max)	Tc (Max)	IP
	Voltage	Current	Voltage	Current	Power					
TAG12V15WB	220-240V AC	0.13A	12V DC	0-1.25A	0-15W	0.8	83%	45°C	80°C	20
TAG12V30WB	220-240V AC	0.5A	12V DC	0-2.5A	0-30W	0.95	85%	45°C	80°C	20
TAG12V60W	220-240V AC	0.37A	12V DC	0-5A	0-60W	0.95	86%	45°C	90°C	20
TAG12V75W-SB	220-240V AC	0.4A	12V DC	0-6.25A	0-75W	0.92	89%	45°C	90°C	20
TAG12V100W-S	200-240V AC	0.6A	12V DC	0-8.33A	0-100W	0.98	90%	45°C	90°C	20
TAG12V180W	200-240V AC	1.2A	12V DC	0-15A	0-180W	0.95	93%	45°C	90°C	20
TAG12V216WB	200-240V AC	1.4A	12V DC	0-18A	0-216W	0.95	92%	45°C	90°C	20
TAGTHIN12V30W	220-240V AC	0.5A	12V DC	0-2.5A	0-30W	0.9	85%	45°C	85°C	20
TAGTHIN12V60WB	220-240V AC	0.5A	12V DC	0-5A	0-60W	0.9	86%	45°C	90°C	20
TAGTHIN12V100W	220-240V AC	0.7A	12V DC	0-8.33A	0-100W	0.95	93%	45°C	90°C	20
TAGTHIN12V200W	220-240V AC	1.5A	12V DC	0-15A	0-200W	0.95	92%	45°C	85°C	20




Mounting Location

Plan View




WARNING:
The unit will generate heat during use. Do not cover with insulation or place near flammable materials.

Top View




Wiring Diagram



Installation

Refer to the "Electrical" section listed in the precautions.
Ensure all components compatible. Configure and pre-test system prior to permanent installation.

- 1. Unscrew and remove the covers from the unit (were applicable).
- 2. Connect AC mains to input (PRI) terminals. No earth is required. Check voltage and polarity.
- 3. Connect LED system on the output (SEC) terminals. Check voltage and polarity.
- 4. Do not cover with insulation or place near flammable materials.
- 5. Secure unit to a solid surface using fixing points with adequate ventilation.
- 6. Maintain a clearance of 50mm around the unit.
- 7. Replace the covers and screw down ensuring cables are firmly clamped.
- 8. Complete electrical safety checks.



SKU	Length	Width	Height	Mounting Points (F1 x F2)
TAG12V15WB	101mm	39.5mm	19.5mm	89mm x 32.1mm
TAG12V30WB	123mm	44.6mm	19.2mm	115.9mm x 13.6mm
TAG12V60W	170mm	44.5mm	28.2mm	160.4mm x 40.6mm
TAG12V75W-SB	170mm	44.5mm	28.2mm	160.4mm x 40.6mm
TAG12V100W-S	170mm	44.5mm	28.2mm	160.4mm x 40.6mm
TAG12V180W	195mm	67.1mm	31.2mm	182.8mm x 62.2mm
TAG12V216WB	195mm	67.1mm	31.2mm	182.8mm x 62.2mm
TAGTHIN12V30W	251mm	30mm	16mm	244.7mm x 26.8mm
TAGTHIN12V60WB	304.6mm	30mm	16.7mm	298.2mm x 26.8mm
TAGTHIN12V100W	320.6mm	30mm	18.2 mm	312.2mm x 26.8mm
TAGTHIN12V200W	356.4mm	32.1mm	22.3mm	347.1mm x 28.6mm