



O Heap & Son (Derby) Ltd



Chase Fire



Key Fire



Kent Fire

Activity: Fire Safety Training (no rig)

Assessors Name:	Chris Ogden	5. Extreme	5 (LOW)	10 (MED)	15 (MED)	20 (HIGH)	25 (HIGH)	
Assessors Signature:	Chris Ogden	4. Major	4 (LOW)	8 (MED)	12 (MED)	16 (MED)	20 (HIGH)	
Assessment Date:	01/01/2019	3. Minor	3 (LOW)	6 (MED)	9 (MED)	12 (MED)	15 (MED)	
Contract Title:	Various clients premises throughout the UK	2. Limited	2 (LOW)	4 (LOW)	6 (MED)	8 (MED)	10 (MED)	
EFFECTED PERSONS:		1. Trivial	1 (LOW)	2 (LOW)	3 (LOW)	4 (LOW)	5 (LOW)	
Visitors			1. Unlikely	2. Rarely	3. Occasional	4. Frequent	5. Inevitable	
Employees	X		RATING					REVIEW PERIOD: 2 Years
Contractors			HIGH RISK					Intolerable - Do not start work
Others (specify)	X		MED RISK					Tolerable - Reduce ALARP. Review annually/change.
			LOW RISK					Tolerable - Monitor. Review annually/change.

No.	Hazard/Aspect Hazardous Event	H&S Consequence Environmental Impact	Pre-control Rating		Control Measures to be Employed	Final Risk Rating		
			L	S		L	S	Risk
1	Environmental issues	Site-specific hazards Adverse weather	3	3	9 On arrival at clients site report to reception and undergo any relevant site inductions. Observe all site safety rules. Wear high viz vest when setting up and conducting practical training. Wear appropriate wet weather gear. Suspend training where weather becomes a safety issue (e.g. high winds).	1	3	3
2	Discharging of fire extinguishers	Release of pressurised substances (extinguishing media)	3	2	6 Demonstrations and supervision of trainee use of fire extinguishers by trained and competent trainer. Extinguisher media to be recycled/disposed of according to company procedure. Some of the extinguisher media may, in certain circumstances harm health. The trainer must refer to the appropriate COSHH assessment and strictly follow the controls suggested. Safety glasses to be worn whilst discharging any extinguisher.	2	2	4

