

Method Statement

| | | |
|---|-------------------------|---------------------|
| Date: 01/01/19 | Review: 01/01/20 | MS No: MD091 |
| Task: Use of Fire Training (no rig) | | |
| Area of Works: On site | | |
| Resources | | |
| Supervision: None required, service engineers trained to work unaccompanied and adhere to any on site local safety practices. | | |
| Operatives: Senior service engineer (authorised and trained to work on training trailer) | | |
| Equipment: Training trailer Source of ignition | | |
| Substances: Assessments will be prepared and available on site and operatives have been fully briefed on the safe use of products. | | |
| Training: Appropriate trade training | | |
| Identified hazards (refer to relevant RAMS and COSHH data) MD090 | | |
| <p>Method of Works:</p> <p>The operator must stand at a distance of not less than 3 metres from the trailer when carrying out demonstrations.</p> <p>Students must stand at a distance of not less than 3 metres from the trailer during demonstrations.</p> <p>Warn students prior to the use of the pyrotechnic flash simulator. Permit those with heart conditions or a nervous disposition to leave the area prior to the demonstration.</p> <p>Regularly inspect the condition of hoses for signs of damage or deterioration.</p> <p>When unattended, gas cylinders to be turned off at the manual control valve.</p> | | |
| <p>Approved by _____</p> <p>O Heap and Son (Derby) Limited</p> | | |