

**SEWAGE SYSTEM COMPLETION CERTIFICATE**

LEEDS GRENVILLE & LANARK DISTRICT HEALTH UNIT

Ont. Building Code Act, R.S.O. 1992, C.23, S.11, O. Reg 403/97

Applicant: <u>Chris Lane</u>			Permit #: <u>8203</u>	
Municipality: <u>North Grenville</u>	Ward:	Lot: <u>5</u> <u>Part 4</u>	Concession:	Assessment Roll #:
Inspection Details	Time: ☒ AM <u>8:45</u> ☐ PM	Date: <u>Dec 22/11</u>	Representing Applicant: <u>Brad Code</u> <u>(Ehovi)</u>	

Centre Street
Burnt's Rapids

1. Sewage System Details:

- a) Septic tank/~~holding~~ tank of working capacity of 3600 Litres constructed of concrete ☒ or plastic ☐ on site ☐ or prefabricated ☒ to serve 3 (no. of bedrooms or units).
Make of Prefabricated Tank Anchor

- b) ~~Leach~~ bed with a total of _____ metres of _____ mm (millimetres) diameter distribution pipe of _____ (type and product description)

Area laid in _____ runs and fed by _____ (gravity, siphon, pump).

- c) Filter bed loading area 30.9 m²

- d) Other treatment units (Manufacturer/Model) waterloo Biofilter flatbed model 16

- e) Other details: well is ~19.6 m to septic tank.

2. Location:

- a) System components installed as shown on application supporting the Permit ☒
b) System components installed as shown on the "As Constructed Plan" ☐

3. Backfill Notification Received On:

Date: Dec. 22/11 Name of Notifier: Brad Code

INSPECTED BY: <u>Deborah Stas</u>	ISSUED BY C.B.O. <u>Mark Yuen</u>	DATE: <u>Jan. 16/12</u>
--------------------------------------	--------------------------------------	----------------------------

Information contained on this form is collected pursuant to the Ontario Building Code Act, 1992 as amended. The information may be released to members of the public upon request for a file search. Questions regarding the collection of this information should be directed to the Chief Building Official of the Leeds, Grenville and Lanark District Health Unit.

FOR OFFICIAL USE ONLY

Permit Faxed Attn: Municipal Building Official Jan 17, 2012 (Date)

☒ Copy to Applicant