

Certificate of Compliance

Certificate Number **20081121-E113714P**
Report Reference **E113714, 1987 December 29**
Issue Date **2008 November 21**

Page 1 of 1



Issued to: **BREMAS ERSCE SPA**

VIA MILANO 26
20060 LISCATE MI ITALY

*This is to certify that
representative samples of*

**COMPONENT - INDUSTRIAL CONTROL EQUIPMENT,
RELAY SOCKETS AND ASSEMBLIES**

Models ES15/2, ES15/4, ES15/2B and ES15/4B

*Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized
licensee of UL in accordance with the Standard(s) indicated on this Certificate..*



Standard(s) for Safety:

UL 508 - Industrial Control Equipment
CSA- C22.2 No. 14 - Industrial Control Equipment

Additional Information:

Ratings
Models ES15/2, ES15/4: 7 A, 300 V.
Models ES15/2B and ES15/4B: 10 A, 300 V.

Only those products bearing the UL Recognized Component Marks for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Mark for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Mark for Canada consists of the UL Recognized Mark for Canada:  and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the

Look for the UL Recognized Component Mark on the product

Issued by:
M. WINDLER, Associate Project Engineer
Underwriters Laboratories Inc.

Reviewed by:
V. R. BAIRD, Engineering Team Leader
Underwriters Laboratories Inc.