

## Supporting Information

# Life Cycle Assessment of Advanced Nutrient Removal Technologies for Wastewater Treatment

*Sheikh M. Rahman<sup>1</sup>, Matthew J. Eckelman<sup>1\*</sup>, Annalisa Onnis-Hayden<sup>1</sup>, and April Z. Gu<sup>1†</sup>*

<sup>1</sup> Department of Civil and Environmental Engineering, Northeastern University, 400 Snell  
Engineering Center, 360 Huntington Ave, Boston, MA 02115, USA

\* Corresponding Author: [m.eckelman@neu.edu](mailto:m.eckelman@neu.edu), Tel: +1 617 373 4256; Fax: +1 617 373 4419

† Co-corresponding Author: [april@coe.neu.edu](mailto:april@coe.neu.edu), Tel: +1 617 373 3631; Fax: +1 617 373 4419

Number of pages: 9

Number of tables: 9

## Contents

**Table S1.** Characteristics of Treatment Plant Alternatives

**Table S2.** Design Criteria and Material, Chemical, and Energy Inventory Basis of the Treatment Processes

**Table S3.** Life cycle inventories per m<sup>3</sup> of influent wastewater

**Table S4.** Chemical Doses and P Removal Rate in Tertiary Processes

**Table S5.** List of Matched U.S.-EI 2.2 Unit Processes

**Table S6.** List of LCA Impact Categories Analyzed in the Current Study

**Table S7.** Ranges of Parameters for Uncertainty Analysis

**Table S8.** LCA Impact Values of the Base-case scenario with Activated Sludge Process

**Table S9.** Normalized score of the level 1 plant with id BNR1

**Table S1.** Characteristics of treatment selected treatment plants with process configurations and technology alternatives to achieve different nutrient treatment levels

<b>Treatment Level</b>	<b>Plant ID</b>	<b>Chemical Addition</b>	<b>Secondary with Nutrient Removal process</b>	<b>Tertiary processes</b>
Level 1	NRP_Chem1	FeCl <sub>3</sub> in Primary clarifier	Modified Ludzack-Ettinger (MLE)	--
	NRP_Chem2	FeCl <sub>3</sub> in Secondary with nutrient removal process	Modified Ludzack-Ettinger (MLE)	--
	NRP_Chem3	FeCl <sub>3</sub> in Primary clarifier and Secondary with nutrient removal process	Modified Ludzack-Ettinger (MLE)	--
	BNR1	--	5-stage Bardenpho	--
	BNR2	--	University of Cape Town process	--
	BNR_Chem1	FeCl <sub>3</sub> in Primary clarifier	5-stage Bardenpho	--
	BNR_Chem2	FeCl <sub>3</sub> in Primary clarifier	University of Cape Town process	--
Level 2	BNR1_EC_Fil1	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	5-stage Bardenpho	Filtration
	BNR2_EC_Fil1	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	University of Cape Town process	Filtration
	BNR1_EC_Fil2	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, FeCl <sub>3</sub> in tertiary process	5-stage Bardenpho	Filtration with continuous backwash
	BNR2_EC_Fil2	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, FeCl <sub>3</sub> in tertiary process	University of Cape Town process	Filtration with continuous backwash
	BNR1_EC_Sed1	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	5-stage Bardenpho	Sedimentation
	BNR2_EC_Sed1	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	University of Cape Town process	Sedimentation

<b>Treatment Level</b>	<b>Plant ID</b>	<b>Chemical Addition</b>	<b>Secondary with Nutrient Removal process</b>	<b>Tertiary processes</b>
	BNR1_EC_Sed2	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	5-stage Bardenpho	Ballasted Sedimentation
	BNR2_EC_Sed2	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	University of Cape Town process	Ballasted Sedimentation
	MBR1_EC	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	5-stage Bardenpho	Membrane Filtration
	MBR2_EC	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	University of Cape Town process	Membrane Filtration
Level 3	BNR1_EC_Fil1_Fil2	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	5-stage Bardenpho	Filtration with continuous backwash; Filtration
	BNR2_EC_Fil1_Fil2	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	University of Cape Town process	Filtration with continuous backwash; Filtration
	BNR1_EC_Sed1_Fil2	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	5-stage Bardenpho	Sedimentation; Filtration with continuous backwash
	BNR2_EC_Sed1_Fil2	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	University of Cape Town process	Sedimentation; Filtration with continuous backwash
	BNR1_EC_Sed2_Fil2	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	5-stage Bardenpho	Ballasted Sedimentation; Filtration with continuous backwash
	BNR2_EC_Sed2_Fil2	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	University of Cape Town process	Ballasted Sedimentation; Filtration with continuous backwash

<b>Treatment Level</b>	<b>Plant ID</b>	<b>Chemical Addition</b>	<b>Secondary with Nutrient Removal process</b>	<b>Tertiary processes</b>
	BNR1_EC_Sed2_MF	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	5-stage Bardenpho	Sedimentation; Membrane Filtration
	BNR2_EC_Sed2_MF	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	University of Cape Town process	Sedimentation; Membrane Filtration
	BNR1_EC_MF_RO	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	5-stage Bardenpho	Membrane filtration; Reverse Osmosis
	BNR2_EC_MF_RO	FeCl <sub>3</sub> in Primary clarifier, methanol in Secondary with nutrient removal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> in tertiary process	University of Cape Town process	Membrane filtration; Reverse Osmosis

**Table S2.** Design Criteria and Material, Chemical and Energy Inventory Basis of the Treatment Processes

<b>Process</b>	<b>Design criteria</b>	<b>Material inventory and basis</b>
Primary clarifier	Surface overflow rate: 800-1000 gal/ ft <sup>2</sup> .d Retention time: 2-2.5 hrs.	Concrete & steel: based on size of the clarifier. Volume of concrete and steel were normalized to the per m <sup>3</sup> of wastewater treated by dividing with total volume of water treated in its lifetime of 20 years Operation energy: energy required to operate the clarifier collected from literature <sup>1-2</sup> Chemical: when chemical P removal was intended FeCl <sub>3</sub> is added as coagulant. Loading of Ferric are estimated from the BioWin design data
Secondary with nutrient removal process	SRT: 10 days MLSS: 2000-2500 mg/L	Concrete & steel: based on size of the reactor designed in BioWin. Volume of concrete and steel were normalized to the per m <sup>3</sup> of wastewater treated by dividing with total volume of water treated in its lifetime of 20 years Operation Energy: Energy for recycle flows, aeration, are calculated based on the BioWin design data Chemical: Methanol is added when external carbon is required for advanced nutrients (both N and P) removal. The loads are estimated using BioWin model data Ferric is added for chemical P removal (when necessary).
Secondary clarifier	Surface overflow rate: 400-700 gal/ ft <sup>2</sup> .d Retention time: 2-2.5 hrs.	Concrete, Steel and Operation energy are estimated as the primary clarifier. No chemical is added.
Filtration	Filtration rate: 80-400 L/m <sup>2</sup> .min; Sand layer depth: 360 mm (conventional); 1200 mm (deep-bed)	Energy is estimated from the literature <sup>1-2</sup> Chemical: Alum is added to traditional filtration and FeCl <sub>3</sub> is added to filtration with continuous backwash process. The chemical loads are collected from the literature <sup>3-5</sup>
Enhanced Sedimentation	Flow rate: 10-15 gal/ft <sup>2</sup> .min	Energy is estimated from the literature <sup>1-2</sup> Chemical: Alum is added for P removal which is collected from literatures <sup>3-4,6-7</sup>
Membrane filtration	Flux rate: 10-40 gal/ft <sup>2</sup> .d	Energy is estimated from the literature <sup>1-2</sup> Chemical: Alum is added for P removal which is collected from literatures <sup>3-4</sup> , NaOCl for membrane cleaning <sup>8</sup>
Reverse osmosis	Flux rate: 8-12 gal/ft <sup>2</sup> .d	Energy is collected from the literature <sup>1-2</sup>

Reactor sizes are determined from the BioWin design. By using typical reactor wall thickness and roof properties, and reinforcement steel usages, volume and weight of concrete and steels are estimated from the designed rector size.

**Table S3.** Life cycle inventories per m<sup>3</sup> of influent wastewater

Level	Plant ID	Electricity kWh	Concrete m <sup>3</sup>	Steel kg	FeCl <sub>3</sub> g	Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> g	Methanol g	NaOCl g
Level 1	NRP_Chem1	0.28	1.345E-05	2.110E-03	26.12	--	--	--
	NRP_Chem2	0.28	1.345E-05	2.110E-03	26.12	--	--	--
	NRP_Chem3	0.28	1.345E-05	2.110E-03	26.12	--	--	--
	BNR1	0.29	1.804E-05	2.831E-03	--	--	--	--
	BNR2	0.35	1.710E-05	2.684E-03	--	--	--	--
	BNR_Chem1	0.29	1.804E-05	2.831E-03	8.71	--	--	--
	BNR_Chem2	0.35	1.710E-05	2.684E-03	8.71	--	--	--
Level 2	BNR1_EC_Fil1	0.30	1.817E-05	2.851E-03	8.71	30.40	15.50	--
	BNR2_EC_Fil1	0.35	1.723E-05	2.704E-03	8.71	30.40	17.00	--
	BNR1_EC_Fil2	0.30	1.831E-05	2.874E-03	31.05	--	15.50	--
	BNR2_EC_Fil2	0.35	1.738E-05	2.726E-03	31.05	--	17.00	--
	BNR1_EC_Sed1	0.30	1.819E-05	2.854E-03	8.71	136.80	15.50	--
	BNR2_EC_Sed1	0.35	1.725E-05	2.707E-03	8.71	136.80	17.00	--
	BNR1_EC_Sed2	0.30	1.818E-05	2.852E-03	8.71	153.90	15.50	--
	BNR2_EC_Sed2	0.35	1.724E-05	2.705E-03	8.71	153.90	17.00	--
	MBR1_EC	0.40	1.804E-05	2.831E-03	8.71	6.30	15.50	5.00
	MBR2_EC	0.45	1.710E-05	2.684E-03	8.71	6.30	17.00	5.00
Level 3	BNR1_EC_Sed1_Fil2	0.30	1.846E-05	2.897E-03	31.05	136.80	22.00	--
	BNR2_EC_Sed1_Fil2	0.36	1.752E-05	2.750E-03	31.05	136.80	23.60	--
	BNR1_EC_Sed2_Fil2	0.30	1.845E-05	2.895E-03	31.05	153.90	22.00	--
	BNR2_EC_Sed2_Fil2	0.36	1.751E-05	2.748E-03	31.05	153.90	23.60	--
	BNR1_EC_Fil1_Fil2	0.30	1.844E-05	2.893E-03	31.05	30.40	22.00	--
	BNR2_EC_Fil1_Fil2	0.36	1.750E-05	2.746E-03	31.05	30.40	23.60	--
	BNR1_EC_Sed2_MF	0.41	1.818E-05	2.852E-03	8.71	160.20	22.00	5.00
	BNR2_EC_Sed2_MF	0.46	1.724E-05	2.705E-03	8.71	160.20	23.60	5.00
	BNR1_EC_MF_RO	2.40	1.804E-05	3.321E-03	8.71	6.30	22.00	5.00
BNR2_EC_MF_RO	2.45	1.710E-05	3.174E-03	8.71	6.30	23.60	5.00	

**Table S4.** Chemical Doses and P Removal Rate in Tertiary Processes<sup>3-4</sup>

Treatment Processes	FeCl <sub>3</sub>	Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub>	NaOCl	Removal Rate
	g/ m <sup>3</sup> WW	g/ m <sup>3</sup> WW	g/ m <sup>3</sup> WW	%
Filtration	--	30.	--	81
Filtration with continuous backwash	22	--	--	96
Sedimentation	--	137	--	97
Ballasted Sedimentation	--	154	--	93
Membrane Filtration	--	6	5	94
Reverse Osmosis	--	--	--	99

**Table S5.** List of Matched U.S.-EI 2.2 Unit Processes

Item	U.S.-EI 2.2 unit processes used in LCA model
Electricity	Electricity mix/US with US electricity
Concrete	Concrete, normal, at plant/ CH U with US electricity
Reinforcing steel	Reinforcing Steel , at plant/ RER U with US electricity
FeCl <sub>3</sub>	Iron (III) chloride, 40% in H <sub>2</sub> O, at plant/ CH with US electricity U
Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub>	Aluminium sulphate, powder, at plant/ RER with US electricity U
Methanol	Methanol, at plant/ GLO with US electricity U
NaOCl	Sodium hypochlorite, 15% in H <sub>2</sub> O, at plant/RER with US electricity U



**Table S6.** List of LCA Impact Categories Analyzed in the Current Study

<b>Impact Categories</b>	<b>Unit</b>	<b>Rationale/Approach</b>	<b>References</b>
Eutrophication potential	kg N eq.	Based on the potency of causing eutrophication in water body. It measures the equivalent eutrophication of a chemical in terms of nitrogen	9-10
Acidification potential	mol H <sup>+</sup> eq.	Based on the potential wet or dry acid deposition in atmosphere. Acidification potential is characterized by equivalent mol of H <sup>+</sup>	9-11
Global warming potential	kg CO <sub>2</sub> eq.	Global warming based on chemical's radiative force and lifetime in atmosphere. Global warming potency of a chemical is expressed as that of equivalent CO <sub>2</sub>	9-11
Ozone depletion potential	kg CFC-11 eq.	Based on chemical's reactivity and potential to destroy ozone in atmosphere. Ozone depletion is characterized by comparing to CFC-11 equivalency.	9-11
Ecotoxicity Potential	CTUe	Based on the potency of causing ecological harm in air, water, soil. It estimates the potentially affected fraction of species (PAF) integrated over time	9,12
Human-carcinogenic potential	CTUh	Based on the potential of causing cancer when a chemical is released to the air, water or soil. It is estimated by cancer related morbidity increase in the total human population per unit mass of an emitted chemical.	9,12
Human non-carcinogenic potential	CTUh	Potential of non-cancer related health effects from chemical emission. It is estimated by morbidity increase due to non-cancer related effects in the total human population per unit mass of an emitted chemical	9,12

**Table S7.** Ranges of parameters for Uncertainty Analysis

<b>Processes</b>	<b>FeCl<sub>3</sub></b>		<b>Al<sub>2</sub>(SO<sub>4</sub>)<sub>3</sub></b>		<b>Additional Electricity</b>	
	<b>g/ m<sup>3</sup> WW</b>		<b>g/ m<sup>3</sup> WW</b>		<b>kWh/m<sup>3</sup></b>	
	<b>Min</b>	<b>Max</b>	<b>Min</b>	<b>Max</b>	<b>Min</b>	<b>Max</b>
Filtration	--	--	24	36	0.003	0.005
Filtration with continuous backwash	17.9	26.8	--	--	0.004	0.007
Sedimentation	--	--	72	200	0.004	0.008
Ballasted Sedimentation	--	--	57	250	0.004	0.008
Membrane filtration	--	--	5	8	0.07	0.14
Reverse Osmosis	--	--			1.5	3

Additionally, methanol is added to simulate the uncertainty involved with influent C to P ratio (C/P). Design C/P ratio is 25 and C/P of the worst case scenario is assumed to be 15. Methanol requirement to raise the C/P ratio from 15 to 25 is 80 mg/L for the influent selected in the study. Hence the range of uncertainty for methanol addition is 0 to 80 mg/L for each of the plants.

**Table S8.** Life Cycle Impact Assessment Results for the Base-case scenario with Activated Sludge Process

Impact category	Total	Material	Chemical Secondary	Electricity Secondary	Effluent	Chemical Primary	Electricity Primary	Direct Emission
Eutrophication (kg N eq)	0.0546	0	0	0.0005	0.0541	0	0	0
Global warming (kg CO2 eq)	0.2300	0.0065	0	0.1373	0	0	0.0042	0.0819
Acidification (kg SO2 eq)	9.9E-4	2.2E-5	0	9.4E-4	0	0	2.8E-5	0
Ozone depletion (kg CFC-11 eq)	6.7E-9	2.9E-10	0	6.2E-9	0	0	1.9E-10	0
Ecotoxicity (CTUe)	0.138	0.029	0	0.105	0	0	0.003	0
Carcinogenics (CTUh)	1.0E-8	2.9E-9	0	7.0E-9	0	0	2.1E-10	0
Non carcinogenics (CTUh)	7.2E-9	2.0E-9	0	5.1E-9	0	0	1.5E-10	0

Base-case scenario is designed with activated sludge process only to remove BOD only. The effluent TN and TP of the scenario are 25.5 mg/L and 3.96 mg/L respectively.

**Table S9.** Normalized score of the Level 1 plant with id BNR1

Impact category	Unit	Impact Score per m3	Impact Score per year	Normalization factor per year*	Normalized score
Eutrophication	kg N eq	0.0165	228666.67	6.60E+09	3.46E-05
Carcinogenics	CTUh	1.64E-08	0.226	1.16E+05	1.95E-06
Non carcinogenics	CTUh	3.10E-08	0.428	3.21E+05	1.33E-06
Ecotoxicity	CTUe	0.246	3395997.76	3.32E+12	1.02E-06
Global warming	kg CO2 eq	0.994	15227345.58	7.40E+12	1.86E-06
Ozone depletion	kg CFC-11 eq	1.08E-08	0.149	4.90E+07	3.04E-09
Acidification	kg SO2 eq	0.0016	21941.79	2.80E+10	7.84E-07

\* Normalization factors are collected from Ryberg *et al.*, which is based on 2008 US inventory data.<sup>13</sup>

We have estimated the normalized score of all the impact categories for a Level 1 plants with id BNR1 as reported in Table S9. Normalized score is calculated by dividing the impact score by the normalization factors, which are the total impacts in each category in the US based on 2008 inventory data as reported in Ryberg *et al.*<sup>13</sup> These normalized scores allow for comparison of plant-level results across impact categories, relative to US totals.

## References

- (1) EPRI *Water and sustainability: U.S. electricity consumption for water supply & treatment—The next half century*; Palo Alto, CA: 2000. 1006787, 2002.
- (2) Pasqualino, J. C.; Meneses, M.; Castells, F., Life cycle assessment of urban wastewater reclamation and reuse alternatives. *J. Ind. Ecol.* **2011**, *15* (1), 49-63.
- (3) Benisch, M.; Clark, D.; Neethling, J. B.; Fredrickson, H. S.; Gu, A., Tertiary phosphorus removal pilot tests technology limits in Coeur D'Alene, ID. *Water Pract.* **2007**, *1* (5), 1-13.
- (4) Gu, A. Z.; Liu, L.; Onnis-Hayden, A.; Smith, S.; Gray, H.; Houweling, D.; Takács, I. *Phosphorus fractionation and removal in wastewater treatment- implications for minimizing effluent phosphorus*; Water Environment Research Foundation, Report no. NUTR1R061: 2014.
- (5) Bluewater-technologies <https://http://www.bluewater-technologies.com/products/bluepro.html> (accessed January, 2013).
- (6) Degremont Technologies [http://www.degremont-technologies.com/IMG/pdf/DENSADEG\\_US\\_Infilco.pdf](http://www.degremont-technologies.com/IMG/pdf/DENSADEG_US_Infilco.pdf) (accessed January, 2013).
- (7) Evoqua Water Technologies [http://www.evoqua.com/en/products/separation\\_clarification/ballasted-clarifiers/Pages/comag-system.aspx](http://www.evoqua.com/en/products/separation_clarification/ballasted-clarifiers/Pages/comag-system.aspx) (accessed January, 2013).
- (8) Igos, E.; Benetto, E.; Venditti, S.; Kohler, C.; Cornelissen, A.; Moeller, R.; Biwer, A., Is it better to remove pharmaceuticals in decentralized or conventional wastewater treatment plants? A life cycle assessment comparison. *Sci. Total Environ.* **2012**, *438* (0), 533-540.
- (9) Bare, J. C., TRACI 2.0: The tool for the reduction and assessment of chemical and other environmental impacts 2.0. *Clean Technol. Environ. Policy* **2011**, *13* (5), 687-696.
- (10) Bare, J. C.; Norris, G. A.; Pennington, D. W.; McKone, T., TRACI: The tool for the reduction and assessment of chemical and other environmental impact. *J. Ind. Ecol.* **2002**, *6* (3-4), 49-78.
- (11) Norris, G. A., Impact characterization in the Tool for the Reduction and Assessment of Chemical and other environmental Impacts. *J. Ind. Ecol.* **2002**, *6* (3□4), 79-101.
- (12) Rosenbaum, R.; Bachmann, T.; Gold, L.; Huijbregts, M.; Jolliet, O.; Juraske, R.; Koehler, A.; Larsen, H.; MacLeod, M.; Margni, M.; McKone, T.; Payet, J.; Schuhmacher, M.; van de Meent, D.; Hauschild, M., USEtox—the UNEP-SETAC toxicity model: recommended characterisation factors for human toxicity and freshwater ecotoxicity in life cycle impact assessment. *Int. J. Life Cycle Assess.* **2008**, *13* (7), 532-546.
- (13) Ryberg, M.; Vieira, M. D. M.; Zgola, M.; Bare, J.; Rosenbaum, R. K., Updated US and Canadian normalization factors for TRACI 2.1. *Clean Technol. Environ. Policy* **2013**, *16* (2), 329-339.