

# PHYSICAL TESTING REPORT



**Paper Graphics**  
Diva Innovation Centre  
Crompton Way  
Crawley  
West Sussex  
RH10 9QR

FAO: Ms. Michelle Dellow

**Report of Tests on:** Stickybits anti-slip floor laminating film

**Your Reference:** FG125

**Lucideon Reference:** UK20408-3214

**Date Reported:** 05-Feb-2020

**Order Number:** BACS

**Date Logged:** 27-Jan-2020

**Date(s) of Test(s):** 03-Feb-2020 to 03-Feb-2020

## Inclined Platform Test for Slip Resistance In Shod Conditions

DIN 51130:2014

No.	Operator 1 - Angle of Inclination	Operator 2 - Angle of Inclination
	°	°
1	6.6	5.8
2	5.5	5.6
3	6.6	6.0

Description of Test Specimen(s): Anti-slip laminate flooring

Average of Six Shod Results (Corrected): 7.7 °

The critical angle at which a test person reaches the limit of safe walking on an inclined plane is used as a measure of slip resistance.

Corrected Mean Overall Acceptance Angle greater than or equal to 6° and less than or equal to 10° = Slip Resistance Class R9.

Corrected Mean Overall Acceptance Angle >10° and less than or equal to 19° = Slip Resistance Class R10.

Corrected Mean Overall Acceptance Angle >19° and less than or equal to 27° = Slip Resistance Class R11.

Corrected Mean Overall Acceptance Angle >27° and less than or equal to 35° = Slip Resistance Class R12.

Corrected Mean Overall Acceptance Angle >35° = Slip Resistance Class R13.

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

**End of Test Report**

Mr Simon Hall  
Manager

This report is issued in accordance with the Conditions of Business of Lucideon Limited and relates only to the sample(s) tested. No responsibility is taken for the accuracy of the sampling unless this is done under our own supervision. This report shall not be reproduced in part without the written approval of Lucideon Limited, nor used in any way as to lead to misrepresentation of the results or their implications.

Lucideon is the trading name of Lucideon Limited. Registered in England No. 1960455.

Lucideon Limited  
Queens Road, Penkull  
Stoke-on-Trent  
Staffordshire ST4 7LQ

T +44 (0)1782 764428  
enquiries@lucideon.com  
www.lucideon.com