

## Product Certification Schedule

Schedule No: 180/001/046

Licensee: SURTEL KABLO SANAYII A.S., SEFAKOY FEVZI CAKMAK CADDESİ, 9 KUCUKCEKMECE 34295, ISTANBUL, TURKEY

Factory: SURTEL KABLO SANAYII A.S., SEFAKOY FEVZI CAKMAK CADDESİ, 9 KUCUKCEKMECE 34295, ISTANBUL, TURKEY

Specification: BS 5467:2016 Incorporating Corrigendum No. 1 Electric cables - Thermosetting insulated, armoured cables of rated voltages of 600/1000V and 1900/3300V for fixed installations - Specification.

Type of Cable: Tables 5, 6, 7 and 8  
Two-core, three-core, four-core and five-core 600/1000V cables with copper conductors

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm to 120sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. Class 2, circular conductor. 25sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. Class 2, shaped conductor. 1.5sqmm to 70sqmm nominal cross-sectional area of conductors inclusive. Five-core. Class 2, circular conductor. Sheath - Type 9. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: SURTEL

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 07/07/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 27/06/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

