

CE Certificate of Conformity

Ventcroft Ltd. Fire Performance Control Cables

The products listed below conform to the requirements of the declared standards and as such conform to the requirements of the EU Directive: Low Voltage Directive 2006/95/EC

NoBurn Platinum

BS7629-1:2015 Electric Cables- Specification for 300/500 V fire resistant, screened, fixed installation cables having low emission of smoke and corrosive gases when affected by fire. Multicore cables.

Declared standards approvals: BASEC License Certificate 152/001 LPCB Certificate 682a/01

NoBurn Plus

BS7629-1:2015 Electric Cables- Specification for 300/500 V fire resistant, screened, cables having low emission of smoke and corrosive gases when affected by fire. Multicore cables

Declared standards approvals: BASEC License Certificate 152/001 LPCB Certificate 682d/01 Ventcroft Limited Faraday Road Astmoor Industrial Estate Runcorn, Cheshire WA7 1PE UK

Telephone: 01928 581098 Fax: 01928 581099 E-Mail: info@ventcroft.co.uk Web: www.ventcroft.co.uk



Fire Performance Cable



Fire Cable Clips



Date 1st January 2017 Ian Rotheram Technical Director External Sounders



Disabled Person Alarm



