

Product Certification Schedule

Schedule No: 017/004/321
Licensee: PRYSMIAN CABLES & SYSTEMS LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU
Factory: PRYSMIAN CABLES & SYSTEMS LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU
Specification: BS 7629-1:1997 Incorporating Amendment Nos. 1 and 2 300/500V fire resistant electric cables having low emission of smoke and corrosive gases when affected by fire. Part 1. Multicore cables
Type of Cable: Table 2 - Dimensions of cables
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 1.5sqmm to 2.5sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. Class 1 and Class 2 conductors. Sheath - LTS3. Insulation - EI5.
Origin Thread: Not applicable
Origin Mark: PRYSMIAN (B) or (B) PRYSMIAN (FP200 FLEX)

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/08/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 02/08/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

