

Product Certification Schedule

Schedule No: 179/001/072

Licensee: SEVAL KABLO AYDINLATMA CIH. ITH. IH. SAN. TIC. A.S., HACI EYUP MAH. 3119, SK. NO:5 UCLER, 20195 DENIZLI, TURKEY

Factory: SEVAL KABLO AYDINLATMA CIH. ITH. IH. SAN. TIC. A.S., HACI EYUP MAH. 3119, SK. NO:5 UCLER, 20195 DENIZLI, TURKEY

Specification: BS 6724:1997 & A3:2008: Electric cables - Thermosetting insulated, armoured cables for voltages of 600/1000V and 1900/3300V having low emission of smoke and corrosive gases when affected by fire

Type of Cable: Tables 6, 8, 10 and 13
Two-core, three-core, four-core and five-core 600/1000V cables with stranded copper conductors

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm to 400sqmm nominal cross-sectional area of conductors inclusive.
Two-core to four-core inclusive.
1.5sqmm to 70sqmm nominal cross-sectional area of conductors inclusive.
Five-core.
Sheath - LTS1. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: SEVAL KABLO or SK or 179/001 or HAE or SVL

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 31/05/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 31/05/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

