



DOMESTIC LIQUID FUEL FIRED PRESSURE JET APPLIANCE SERVICE, COMMISSIONING & INSPECTION RECORD

Report Ref No: **P011 0343187**

1a. ENGINEER DETAILS

Engineer Name: KEVIN LAIRD
 Registration No: _____
 Company: ALEXANDER HEATING
 Address: 1 PITKERRIE FARM COTTES
FEARNS
TAIN
 Postcode: WD2 7JW Tel: 0796841919
 Signed: _____

1b. PROPERTY ADDRESS

Name: SEAN BISHOP
 Address: WESTER WHIMMILL
 Postcode: _____ Tel: 07767 837740
 Date of visit: 16/11/22 Time of arrival: _____ Time of depart: _____
 Name of Recipient: _____ Signature of Recipient: _____

1c. CUSTOMER NAME & ADDRESS (if different)

Name: _____ Address: _____
 Postcode: _____ Tel: _____
 Name of Recipient: _____ Signature of Recipient: _____

VISIT (tick as appropriate)

Appliance heat output rating: _____ kW Commission: Service: Breakdown: Return Visit:
 Immediate and/or Potential Safety and/or Environmental Risks have been identified. Warning Label(s) attached:

CUSTOMER ADVISED

APPLIANCE DETAILS

Appliance make: GRANT Model: 70 Serial No. _____
 Burner make: PIELLO Model: R013 Serial No. _____

LIQUID FUEL COMBUSTION APPLIANCE/BURNER DETAILS (tick applicable)

Appliance Location:	External	Internal	Other	Wall mounted	Floor Standing
Appliance Type:	Boiler	Range Cooker	Other		
Burner Type:	Single Stage	Two Stage	Modulating	Yellow Flame	Blue Flame
Flue Chimney Type:	Natural Draught	Balanced Flue	Low Level Discharge		
Accessibility:	Fully accessible	Partially accessible	Not safely accessible		
Liquid Fuel Identified as:	Class C2 Kerosene	Class D Gas Oil	Other (e.g. Bio/Blend):	B30K	B100


SERVICE RECORD

1 Electrical Safety Provision & Operation	INSPECTED /, X or W	COMMENTS/RECOMMENDATIONS	IMMEDIATE RISK IDENTIFIED	POTENTIAL RISK IDENTIFIED	WARNING NOTICE ISSUED
2 Oil Storage & Supply System	✓	AIR VENT CRACKED & LOOSE. TANK WITHIN 50CM OF WOODEN FENCE			
3 Combustion / Ventilation Air Supplies	✓				
4 Flue / Chimney System	✓				
5 Burner	✓				
6 Appliance	✓				

TEST RECORDS

Fuel pump outlet pressure	<u>115</u> psi / bar	Fuel pump inlet pressure/vacuum	<u>1</u> psi / bar	Smoke No	<u>0</u>	Remote Acting Firevalve Tested	✓
Fuel draught min/max	<u>11mm</u> - <u>14mm</u> w.g	Air shutter setting	<u>45</u>	Efficiency Net	<u>87.9</u>	Efficiency Gross	<u>87.9</u>
CO ₂	<u>12.0</u> %	Excess Air	<u>4.7</u> %	NOX	<u>33</u> ppm/mg/KWh	SOx ppm	<u>0.60</u>
Flue Gas Temperature net	<u>293.4</u> °C	Flue Gas Temperature gross	<u>4.7</u> °C	Nozzle	<u>WAVFOSS</u>	Size	<u>0.60</u>
						Spray Angle	<u>60</u>
						Spray Pattern	<u>EH</u>

ALEXANDER HEATING



INVOICE

Kevin Laird

Joan Bishop

Alexander Heating

Wester Whinhill

1 Pitkerrie Farm Cottages

Dornoch

Fearn

IV25 3RW

Tain

IV20 1TN

Work carried out on: 16/11/2022

Oil boiler service £120

Total £120.00

TOTAL COST: £120.00

Bank Details:

Sort Code: 82-61-16

Account Number: 40392820

Kevin Laird