



## DECLARATION OF PERFORMANCE (DoP)

Acc. to EN 50575:2014+A1:2016

**5P06987-20-1063**

### Product

Type	EXQ 5G2,5
Unique identification	1063
Batch no	See label on the product
Intended use	Power supply in buildings

Manufacturer	Notified body
amo installationskabel AB Kabelvägen 5 364 43 Alstermo +46(0)481 50896 installation@amokabel.com	SP Technical Research Institute of Sweden Nr. 0402 Enligt System 3 (bilaga V del 1.4 för CPR)

### Declared performance

Flame spread	Smoke production	Flaming droplets	Acidity
According to : EN 50399	According to : EN 50399	According to : EN 50399	According to : EN 60754-2
<b>D<sub>ca</sub></b>	<b>s1</b>	<b>d2</b>	<b>a1</b>

### Reaction to fire :

***D<sub>ca</sub>- s1, d2, a1***

*This declaration of performance is issued under the sole responsibility of the manufacturer .*

*Signed for and on behalf of the manufacturer by :*

Michael Boman, Technical manager  
 \_\_\_\_\_  
 (Name and position )

Alstermo, 2017-06-06  
 \_\_\_\_\_  
 (Place and date of issue )

  
 \_\_\_\_\_  
 (Signature )