



DECLARATION OF PERFORMANCE (DoP)

Acc. to EN 50575:2014+A1:2016

5P06987-22-1002

Product

Type	EXLQ 4G1,5
Unique identification	1002
Batch no	See label on the product
Intended use	Power supply in buildings

Manufacturer	Notified body
amo installationskabel AB Kabelvägen 5 364 43 Alstermo +46(0)481 50896 installation@amokabel.com	SP Technical Research Institute of Sweden Nr. 0402 Enligt System 3 (bilaga V del 1.4 för CPR)

Declared performance

Flame spread	Smoke production	Flaming droplets	Acidity
According to : EN 50399	According to : EN 50399	According to : EN 50399	According to : EN 60754-2
D_{ca}	s2	d2	a1

Reaction to fire :

D_{ca}- s2, d2, a1

This declaration of performance is issued under the sole responsibility of the manufacturer .

Signed for and on behalf of the manufacturer by :

Michael Boman, Technical manager

 (Name and position)

Alstermo, 2017-06-06

 (Place and date of issue)



 (Signature)