



DECLARATION OF PERFORMANCE (DoP)

Acc. to EN 50575:2014+A1:2016

5P06987-25-1079

Product

| | |
|-----------------------|---------------------------|
| Type | FQQ 3G2,5 |
| Unique identification | 1079 |
| Batch no | See label on the product |
| Intended use | Power supply in buildings |

| Manufacturer | Notified body |
|--|--|
| amo installationskabel AB Kabelvägen 5 364 43 Alstermo +46(0)481 50896 installation@amokabel.com | SP Technical Research Institute of Sweden Nr. 0402 Enligt System 3 (bilaga V del 1.4 för CPR) |

Declared performance

| Flame spread | Smoke production | Flaming droplets | Acidity |
|-------------------------|-------------------------|-------------------------|---------------------------|
| According to : EN 50399 | According to : EN 50399 | According to : EN 50399 | According to : EN 60754-2 |
| D_{ca} | s1 | d2 | a1 |

Reaction to fire :

D_{ca}- s1, d2, a1

This declaration of performance is issued under the sole responsibility of the manufacturer .

Signed for and on behalf of the manufacturer by :

Michael Boman, Technical manager
(Name and position)

Alstermo, 2017-06-06
(Place and date of issue)


(Signature)