



## DECLARATION OF PERFORMANCE (DoP)

Acc. to EN 50575:2014+A1:2016

**6P10018-18-1009**

### Product

|                       |                           |
|-----------------------|---------------------------|
| Type                  | EKK 3G1,5 Tjock Yd        |
| Unique identification | 1009                      |
| Batch no              | See label on the product  |
| Intended use          | Power supply in buildings |

| Manufacturer   | Notified body  |
|--|--|
| amo installationskabel AB<br>Kabelvägen 5<br>364 43 Alstermo<br>+46(0)481 50896<br>installation@amokabel.com | SP Technical Research Institute of Sweden<br>Nr. 0402<br>Enligt System 3<br>(bilaga V del 1.4 för CPR) |

### Reaction to fire :

*E<sub>ca</sub>*

*This declaration of performance is issued under the sole responsibility of the manufacturer .*

*Signed for and on behalf of the manufacturer by :*

Michael Boman, Technical manager  
*(Name and position )*

Alstermo, 2017-06-06  
*(Place and date of issue )*

  
*(Signature )*