



## DECLARATION OF PERFORMANCE (DoP)

Acc. to EN 50575:2014+A1:2016

**7P00830-23-1147**

### Product

|                       |                           |
|-----------------------|---------------------------|
| Type                  | Tvinnad H07Z1-U 3G1,5     |
| Unique identification | 1147                      |
| Batch no              | See label on the product  |
| Intended use          | Power supply in buildings |

| Manufacturer                                                                                                 | Notified body                                                                                          |
|--------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------|
| amo installationskabel AB<br>Kabelvägen 5<br>364 43 Alstermo<br>+46(0)481 50896<br>installation@amokabel.com | SP Technical Research Institute of Sweden<br>Nr. 0402<br>Enligt System 3<br>(bilaga V del 1.4 för CPR) |

### Declared performance

| Flame spread            | Smoke production        | Flaming droplets        | Acidity                   |
|-------------------------|-------------------------|-------------------------|---------------------------|
| According to : EN 50399 | According to : EN 50399 | According to : EN 50399 | According to : EN 60754-2 |
| <b>D<sub>ca</sub></b>   | <b>s2</b>               | <b>d1</b>               | <b>a1</b>                 |

### Reaction to fire :

***D<sub>ca</sub>- s2, d1, a1***

*This declaration of performance is issued under the sole responsibility of the manufacturer .*

*Signed for and on behalf of the manufacturer by :*

Michael Boman, Technical manager  
 \_\_\_\_\_  
 (Name and position )

Alstermo, 2017-06-06  
 \_\_\_\_\_  
 (Place and date of issue )



\_\_\_\_\_  
 (Signature )