



DECLARATION OF PERFORMANCE (DoP)

Acc. to EN 50575:2014+A1:2016

7P00830-23-01000

Product

| | |
|-----------------------|---------------------------|
| Type | H05Z1-U 0,75 |
| Unique identification | 01000 |
| Batch no | See label on the product |
| Intended use | Power supply in buildings |

| Manufacturer | Notified body |
|---|--|
| amo specialkabel AB Kabelvägen 5 364 43 Alstermo +46(0)481 50880 special@amokabel.com | SP Technical Research Institute of Sweden Nr. 0402 Enligt System 3 (bilaga V del 1.4 för CPR) |

Declared performance

| Flame spread | Smoke production | Flaming droplets | Acidity |
|-------------------------|-------------------------|-------------------------|---------------------------|
| According to : EN 50399 | According to : EN 50399 | According to : EN 50399 | According to : EN 60754-2 |
| D_{ca} | s2 | d1 | a1 |

Reaction to fire :


D_{ca}- s2, d1, a1

This declaration of performance is issued under the sole responsibility of the manufacturer .

Signed for and on behalf of the manufacturer by :

Urban Sandberg, Technical manager
 (Name and position)

Alstermo, 2017-06-06
 (Place and date of issue)


 (Signature)