



## DECLARATION OF PERFORMANCE (DoP)

Acc. to EN 50575:2014+A1:2016

**7P00830-33-06717**

### Product

Type	H07Z1-K 50
Unique identification	06717
Batch no	See label on the product
Intended use	Power supply in buildings

Manufacturer	Notified body
amo specialkabel AB Kabelvägen 5 364 43 Alstermo +46(0)481 50880 special@amokabel.com	SP Technical Research Institute of Sweden Nr. 0402 Enligt System 3 (bilaga V del 1.4 för CPR)

### Declared performance

Flame spread According to : EN 50399	Smoke production According to : EN 50399	Flaming droplets According to : EN 50399	Acidity According to : EN 60754-2
<b>D<sub>ca</sub></b>	<b>s1</b>	<b>d1</b>	<b>a1</b>

### Reaction to fire :


***D<sub>ca</sub>- s1, d1, a1***

*This declaration of performance is issued under the sole responsibility of the manufacturer .*

*Signed for and on behalf of the manufacturer by :*

Urban Sandberg, Technical manager  
*(Name and position )*

Alstermo, 2017-06-06  
*(Place and date of issue )*

  
*(Signature )*