

# TYPE APPROVAL CERTIFICATE

**This is to certify:**

**That the Electric Power Cable**

with type designation(s)

**RXZ-HF EMC 0,6/1kV, RXZ-HF VFD EMC 1,8/3kV, RXZ-HF VFD EMC 3G 1,8/3kV, RXZ-HF VFD EMC Soft 1,8/3kV**

Issued to

**amo specialkabel AB  
ALSTERMO, Sweden**

is found to comply with

**DNV GL rules for classification – Ships, offshore units, and high speed and light craft**

**Application :**

**General power and lighting. VFD version for variable frequency drives.**

**Products approved by this certificate are accepted for installation on all vessels classed by DNV GL.**

Type	Rated voltage (kV)	Temp. class (°C)
<b>RXZ-HF EMC 0,6/1kV</b>	<b>0,6/1</b>	<b>90</b>
<b>RXZ-HF VFD EMC 1,8/3kV</b>	<b>1,8/3kV</b>	<b>90</b>
<b>RXZ-HF VFD EMC 3G 1,8/3kV</b>	<b>1,8/3kV</b>	<b>90</b>
<b>RXZ-HF VFD EMC Soft 1,8/3kV</b>	<b>1,8/3kV</b>	<b>90</b>

Issued at **Høvik** on **2018-05-30**

This Certificate is valid until **2023-05-29**.

for **DNV GL**

DNV GL local station: **Malmö**

Approval Engineer: **Ivar Bull**

.....  
**Andreas Kristoffersen**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



## Product description

Types: RXZ-HF EMC 0,6/1kV,  
RXZ-HF VFD EMC 1,8/3kV,  
RXZ-HF VFD EMC 3G 1,8/3kV  
RXZ-HF VFD EMC Soft 1,8/3kV

### Construction:

Conductors: Plain/tinned, stranded copper class 2 or class 5  
Core insulation: HF XLPE  
Filler: Flame retardant halogen-free compound  
Inner covering: Lapped or extruded  
Screen (if any): Metal backed PE tape  
Metal covering: Plain/tinned copper wire braid or galvanised steel wire braid  
Outer sheath: SHF 1

### RXZ-HF EMC 0,6/1kV:

No of cores:	Cross sectional area [mm <sup>2</sup> ]
1	1,5 - 300
2	1,5 - 95
3	1,5 - 240
4	1,5 - 95
5	1,5 - 25
6, 7, 10, 12, 14, 16, 19, 24, 25, 27, 37	1,5
7, 9, 10, 14, 16, 19, 24, 27, 37	2,5

### RXZ-HF VFD EMC 1,8/3kV:

No of cores:	Cross sectional area [mm <sup>2</sup> ]
3	16 -240
4	95

### RXZ-HF VFD EMC 3G 1,8/3kV:

No of cores:	Cross sectional area [mm <sup>2</sup> ]
3/3E	16/2,5 - 240/50

### RXZ-HF VFD EMC Soft 1,8/3kV:

No of cores:	Cross sectional area [mm <sup>2</sup> ]
3	120

## Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

## Type Approval documentation

## Tests carried out

	<b>Release</b>	<b>General description</b>	<b>Limitation</b>
DNVGL-CP-0399	2016-03	Class Programme Electric cables	
IEC 60092-350	2014-08	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60092-353	2016-09	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2013-07 2013-09	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance ≥60%

## Marking of product

AMOKABEL RXZ EMC – size – IEC 60092-353- IEC 60332-3-22 - DNVGL 0,6/1kV - YYWW or  
 AMOKABEL RXZ VFD EMC – size – IEC 60092-353 - IEC 60332-3-22 -DNVGL - 1,8/3kV - YYWW or  
 AMOKABEL RXZ VFD EMC 3G –size – IEC 60092-353 - IEC 60332-3-22 - DNV 1,8/3kV - YYWW or  
 AMOKABEL RXZ VFD EMC Soft – size – IEC 60092-353 - IEC 60332-3-22 -DNVGL 1,8/3kV - YYWW

## Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer’s product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE