

DECLARATION OF PERFORMANCE (DoP)

Acc. to EN 50575:2014+A1:2016

5P06987-20-1059

Product

Type	EXQ 3G1,5
Unique identification	1059
Batch no	See label on the product
Intended use	Power supply in buildings

Manufacturer	Notified body
amo installationskabel AB Kabelvägen 5 364 43 Alstermo +46(0)481 50896 installation@amokabel.com	SP Technical Research Institute of Sweden No . 0402 In accordance with System 3 (appendix V part 1.4 according to CPR)

Declared performance

Flame spread According to : EN 50399	Smoke production According to : EN 50399	Flaming droplets According to : EN 50399	Acidity According to : EN 60754-2
D_{ca}	s2	d2	a1

Reaction to fire :

D_{ca}- s2, d2, a1

Dangerous substances : NPD

This declaration of performance is issued under the sole responsibility of the manufacturer .

Signed for and on behalf of the manufacturer by :

Michael Boman, Technical manager

(Name and position)

Alstermo, 2020-03-18

(Place and date of issue)



(Signature)