



Declaration of performance No. 006BauPVo2017-08-01

1. Unique identification code of the product type:

Mechanically operated lock DIN EN 12209

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

9100, 9100F, 9100FL, 9100SP, 9100F-SP, 9100WC, 9100R

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

**When used with an appropriate door closing device
on fire and/or smoke control doors
to fulfill the self-closing requirement of such doors, and thereafter
to ensure that the door remains shut.**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11 (5):

**C.Ed. Schulte GmbH Zylinderschlossfabrik
Friedrichstraße 243
42551 Velbert**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N.N.

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

Notified product certification body MPA NRW DAAKS-No. 0432 performed the determination of the product type on the basis of type testing (including sampling), initial inspection of the manufacturing plant and of the factory production control and continuous surveillance, assessment and evaluation of factory production control and issued the certificate of constancy of performance of the product.

8. European Technical Assessment:

N/A

9. Declared performance:

Harmonised technical specification: DIN EN 12209:2004-03

Essential characteristics	Performance
Self-closing ability	
5.4.2 Closing force	$\leq 15 \text{ N}$
5.1.2 Return force of latch bolt	$\geq 2,5 \text{ N}$
Durability of self-closing action	
5.3.1 Durability of latch action	Grade X: 200.000 test cycles with 120N load on the latch bolt
Ability to maintain door in closed position and not contribute to the spread of fire	
5.5 Suitability for use on fire/smoke doors	Grade 1: suitable for use on fire/smoking resisting doorset assemblies
Control of dangerous substances	
5.1.1 Dangerous substances	The materials in this product do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

The declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Mr. Dipl.-Ing. Richard Rackl, Managing Director, C.Ed. Schulte GmbH Zylinderschlossfabrik

(name and function of the person producing the DoP)

Velbert, August 1st 2017

(place and date of issue)



(signature)