


Blowdown valve for bleeding dirt and sludge

For steam boilers Model 460



EN ASME/ANSI



The water in the boiler contains salts, which are built up by the continuous evaporation. If these salts are not eliminated, bubbles and foam are formed when the density of the water increased.

To prevent these lime deposits forming, the water supply must be suitably treated, with the result that certain salts are changed producing impurities which form sludge and encrusted deposits which then adhere to the sides or the bottom of the boiler and to the combustion tubes, together with particles of dirt, remains of electrodes, carbonic acid, oxygen, etc. This leads to a high level of rust which may:

- Destroy the metal plate of the boiler, causing high maintenance costs.
- Produce thermic voltages, causing cracks in the metal plate and soldering cord.
- Notably slow down thermic transmission, meaning an unnecessary and excessive consumption of fuel.

Specifications

- A the draining section is opened quickly and completely by driving the lever from right to left. The deposits, collected at the bottom of the boiler, are disturbed and sucked up by the sudden air intake which carries them out.
- Direct emptying passage, meaning a high volume and low level of load loss.
- Rotating the lever from left to right causes instant closing, preventing irrevocable losses of water and pressure.
- Seatings and stoppers treated and balanced ensuring a level of tightness higher than that required by EN 12266-1.
- Equipped with a screw for the drainage of the sedimentations.
- Simplicity of design ensures good performance.

Nº. PIECE	PIECE	MATERIAL			
1	Seating	S. steel (EN-1.4028)			
2,6	Plug	S. steel (EN-1.4028)			
3	Cap	Carb. steel (EN-1.1191)			
4,15	Coupling	Graphite			
5	Spring	S. steel (EN-1.4310)			
7	Nut	Carb. steel (EN-1.1141)			
8	Washer	Carb. steel (EN-1.1141)			
9,19	Stud	Carb. steel (EN-1.1181)			
10	Cover	Nodular iron (EN-5.3106)			
11	Rack	S. steel (EN-1.4305)			
12	Rivets	Carb. steel (EN-1.1141)			
13	Gland disc	Bronze (EN-CC491K-GZ)			
14	Valve base	Bronze (EN-CC491K-GC)			
16	Body	Cast steel (EN-1.0619)			
17	Axis with pinion	S. steel (EN-1.4305)			
18	Gland	Nodular iron (EN-5.3106)			
20	Lever	Carb. steel (EN-1.0037 St-37.2)			
21	Elastic gudgeon	Carb. steel (EN-1.1231)			
22	Gauge plate	Aluminium			
23	Seal	Graphite			
24	Flange	Carb. steel (EN-1.0460)			
DN		25 to 50 (EN, ANSI)			
PN		40			
OPERATING CONDITIONS	MAX. ACCEPTABLE PRESSURE PS bar	40	37,1	33,3	30,4
	MAX. ACCEPTABLE TEMPERATURE TS °C	RT	100	200	250

According to demand: Closing surfaces with "stellita n°. 6" DIN-8555.

RT= Room temperature -10°C 50°C.

Efficiency and Emptying

Bleeding processes should coincide as far as possible with moments when the water is at rest or at minimum steam extraction, so that the deposits are collected at the bottom of the boiler.

Carry out bleeding process at least every 8 hours. The effective duration is estimated to be 3-4 seconds although we recommend you keep to the following mathematical model:

To establish the salinity of the water, the quantity of salts extracted per unit of time must be equal to that of the water supply in this same period. Which can be expressed:

$$M \cdot A = S \cdot P$$

Where:

Q = Real steam production of the boiler. (Kg/h).

A = Water supply. (l/h).

M = Salinity of the water supply. (mg/l).

P = Water extracted in the bleeding process. (l/h).

S = Desired salinity inside the boiler. (mg/l).

Q = Specific mass of water inside the boiler. (Kg/l).

p = Working pressure. (bar).

Example:

Q = 1.850 Kg/h.

M = 150 mg/l.

S = 4.000 mg/l.

Q = 1 Kg/l.

p = 20 bar.

P = 72,07 l/h.

C = 18 l/s.

T = 4 s.

-The boiler will bleed itself for 4 seconds every hour.

-If, in accordance with the mathematical model, times shorter or longer than 3-4 seconds are obtained, the bleeding process must be carried out more or less times.

The water to be bled compared to the steam produced is:

$$P = \frac{M}{(S-M)} \cdot Q$$

For the DN the volume (C) in l/s can be calculated as shown in the diagram.



The quotient (P/C) tells us the intervals between bleeding processes and the duration of them (T) in seconds per hour.

The combination of the Continuous desalting valve* and the Blowdown valve for bleeding dirt and sludge* is essential for optimizing the boiler's efficiency, and include its maximum security and availability.

Neither of them can be replaced with others not designed for this specific application. Their moderate cost is depreciated in the short term.

* (See brochure for Models 560 and 560-A).

* (See brochure for Models 260 and 260-A).



DN	25		32		40		50	
CONNECTIONS	I- Flange PN-40 EN-1092-1							
	II - Flange class 300 lbs ASME/ANSI B 16.5							
	I	II	I	II	I	II	I	II
H	179		179		245		245	
L	160		180		200		230	
D	115	125	140	135	150	155	165	165
K	85,00	88,90	100,00	98,40	110,00	114,30	125,00	127,00
I	14,00	19,10	18,00	19,10	18,00	22,20	18,00	19,10
b	18,00	17,50	18,00	19,10	18,00	20,70	20,00	22,30
A	135		170		170		170	
DRILLS N°.	4		4		4		4	
WEIGHT IN Kgs.	8,04	14,01	9,78	15,51	10,75	17,27	12,27	18,27
CODE 2103-460.	8104	81041	8144	81441	8124	81241	8204	82041

VYC industrial, sa
Founded in 1914

www.vycindustrial.com

Avenc del Daví, 22 Pol. Ind. Can Petit 08227 TERRASSA (Barcelona) SPAIN

+34 93 735 76 90

+34 93 735 81 35

✉ 119

@info@vycindustrial.com

Informative brochure, without obligation and subject to our General Sales Conditions.